



EnDev2 Indonesia:

Inspection Guide for Photovoltaic Village Power (PVVP) Systems

Revision June 2015

Compiled by: Robert W Schultz and Amalia Suryani



Implemented by:

giz Deutsche Gesellschaft
für Internationale
Zusammenarbeit (GIZ) GmbH



Contents

| | |
|---|----|
| List of Figures and Tables | 1 |
| Abbreviation | 2 |
| Glossary | 2 |
| 1. Introduction | 3 |
| 2. Inspection Guide Overview | 4 |
| 3. Inspection Preparation | 5 |
| 3.1. List of Equipment | 5 |
| 3.2. Implementation Guide | 5 |
| 3.3. Inspection Process | 7 |
| 3.4. General Tips | 7 |
| 3.5. PVVP DC System | 8 |
| 3.5. PVVP AC System | 9 |
| 4. Technical and Workmanship Checklist | 10 |
| 4.1. Component Compliance | 10 |
| 4.2. Performance Verification | 11 |
| 4.3. Workmanship Quality | 15 |
| 4.4. Photographs | 17 |
| 5. KPI Questionnaire | 22 |
| 6. Technical Summary Sheet | 23 |
| Appendix 1 Technical checklist – component compliance | 25 |
| Appendix 2 Technical checklist – performance verification | 30 |
| Appendix 3 Workmanship checklist | 31 |
| Appendix 4 KPI questionnaire | 33 |
| Appendix 5 Manual for KPI questionnaire | 42 |
| Appendix 6 Technical summary sheet with scoring guideline | 49 |

List of Figures and Tables

| | |
|--|----|
| Figure 1 PV-VP site | 3 |
| Figure 2 EnDev site identification | 6 |
| Figure 3 Inspection flow diagram | 7 |
| Figure 4 Block diagram of PVVP DC system | 8 |
| Figure 5 Block diagram of PVVP AC system | 9 |
| Figure 6 KPI survey | 22 |
| Table 1 List of equipment | 5 |
| Table 2 List of photographs | 20 |

Abbreviation

| | |
|---------|--|
| DGNREEC | Directorate General for New and Renewable Energy and Energy Conservation |
| EnDev | Energising Development (2009 - 2018) |
| GIZ | Gesellschaft für Internationale Zusammenarbeit (German Agency for International Cooperation) |
| GSM | Global System for Mobile Communications |
| KPI | Key Performance Indicators |
| kW | kilo Watt |
| LCD | Liquid crystal display |
| MHP | Micro/mini hydro power |
| PLTS | Pembangkit Listrik Tenaga Surya (solar power plant) |
| PVVP | Photovoltaic Village Power (mini-grid) |
| RMS | Remote monitoring system |
| VMT | Village management team |

Glossary

This glossary briefly describes the interpretation of some terms used frequently in this document.

| | |
|---------------------------|--|
| Coordination Office | Central office of the evaluator(s) and support staff for coordinating the work of the inspection teams, provides logistical support, updates instructions, and undertakes quality assurance of checklists and photographs submitted. |
| Evaluator | Senior expert(s) with experience in off-grid technologies, prepares the inspection teams, coordinates their deployment and performs final evaluation of data. |
| Handheld measuring device | A battery-operated stand-alone portable device, like a multi-meter, clamp meter or thermometer, used for spot measurements. |
| Insufficient | From workmanship scoring: describes an obvious shortcoming, deviating from common best practice. |
| Inspector/Inspection team | Two (2) persons field team conducting site visits and completing all checklists and questionnaires; comprising an experienced technician and an assistant. |
| LCD | Automatic data monitoring device integrated into key components like inverters or charge regulators. |
| RMS | Automatic data monitoring device extracting data from key components, like inverters; usually a computer permanently installed in the powerhouse. |
| Unsecure | Cable or material not connected or secured according to best practices. |
| Unfirm | Poles or materials not stable, but wobbly, with risk of collapse. |

1. Introduction

Energising Development (EnDev) Indonesia's objective is to support sustainable access to modern energy services for rural communities in Indonesia. One key intervention is to support different rural electrification infrastructure projects under various public and private agencies in Indonesia.

EnDev conducted a technical review and baseline data survey for over two hundred (200) 15kW to 150kW solar mini-grid installations (photovoltaic village power/PVVP) across Indonesia, installed by local suppliers under contract with Directorate General for New and Renewable Energy and Energy Conservation (DGNREEC) in 2013 and 2014. Hereafter referred to as the *DGNREEC PVVP Technical Review*.

Specialist technical inspection teams, comprising one (1) experienced technician and one (1) assistant, were recruited for this programme to conduct 2-day site visits, complete prepared checklists and questionnaires and train the beneficiary communities on system operation, maintenance and administration. Findings of these inspections were summarised and submitted to DGNREEC for subsequent follow-up with contractors. In addition, baseline data (through the EnDev Key Performance Indicator/KPI survey methodology) was captured for a comprehensive database on EnDev-supported rural electrification projects.

This Inspection Guide present the checklists, measurements form, and KPI questionnaire, as well as explanatory documentation compiled during this programme and adapted to capture essential lessons learnt.



Figure 1 PV-VP site

All PVVP sites were provided with unique site codes ensuring that all collected technical and socio-economic data is correctly referenced.

Purpose of this Inspection Guide is to record the process and make templates available for future inspections by any interested third parties. First version of this guide was published in October 2013. This updated version includes the latest templates.

For any support regarding guidelines and updated templates for future inspections, third parties can enquire with:

Energising Development (EnDev) Indonesia

Deutsche Gesellschaft für
Internationale Zusammenarbeit (GIZ) GmbH
Gedung De RITZ, Floor 3A
Jl. HOS Cokroaminoto No. 91
Menteng, Jakarta Pusat 10310
Indonesia
T + 62 21 391 5885
F + 62 21 391 5859
Website: <http://endev-indonesia.org>

2. Inspection Guide Overview

Inspection preparation - *conducted by inspector and evaluator prior to site visit*

Preparatory work to be done in order to conduct site survey effectively and efficiently. Described in **Section 3**.



Component compliance - *conducted on site by inspector*

Spread sheet-based checklist comparing all components (type, specifications, quantity, etc.) installed on site between tender specifications and contractor contract. Assessment is done on the basis of “Fulfilled” or “Not Fulfilled”. Purpose is to determine whether contractors neglected to provide any components as legally required under the contract. Described in **Section 4.1**; template included in **Appendix 1**.

Performance verification - *conducted on site by inspector*

Spread sheet-based measurement sheets for spot-check measurements on the performance of key components (solar PV generation capacity, battery charging status, inverter output, and distribution network losses). Evaluation is based on quantitative data collected. Purpose is to determine whether the PV-VP system as a whole operates close to its optimal. Described in **Section 4.2**; template included in **Appendix 2**.

Workmanship checklist - *conducted on site by inspector*

Spread sheet-based checklist of workmanship indicators, clustered into different categories. Evaluation is done according to a scoring system using a rating of 1 to 5 (worst to best). Purpose is to assess whether quality of installation adheres to best practices, safety requirements and overall installation sustainability. Described in **Sections 4.3 and 4.4**; template included in **Appendix 3**.

Key Performance Indicator (KPI) survey - *conducted on site by inspector*

Questionnaire for assessing technical, social and economic aspects. Interviews involve different community stakeholders. Evaluation is based on qualitative and quantitative data. Purpose is to assess the overall sustainability of rural electricity infrastructure and to capture baseline data on technical and non-technical aspects in the community. Described in **Section 5**; template in **Appendix 4** and user manual in **Appendix 5**.



Technical summary sheet - *conducted by evaluator after site visits*

Document (5 to 7 pages) with assessment and scoring results of the technical review, with photographic evidence and recommendations for any corrective actions. Purpose is to provide objective and verifiable information regarding the PV-VP installation status, for possible follow-up with the relevant contractors. Described in **Section 6**; template with scoring guidelines included in **Appendix 6**.

3. Inspection Preparation

3.1. List of Equipment

The inspection visits would require meticulous logistical planning and preparation. Table 1 List of equipment below presents the equipment to be brought by the inspection team to each site, in order to fulfil the tasks at hand.

Table 1 List of equipment

| General equipment | Measuring equipment | Survey forms and training tools |
|--|---|--|
| Introductory mandate letter (laminated) | Clamp meter (AC and DC) | Inspection guide for PVVP |
| GSM cell phone + charger | Digital multi-meter (<i>avometer</i>) | Technical checklist – Component Compliance |
| Handheld GPS device + charger/spare batteries | Digital thermometer (ambient air) | Technical checklist – Performance verification |
| Laptop (with MS Office) | 5 m Measuring tape (for distance) | Technical checklist – Workmanship quality |
| Calculator | | KPI PVVP questionnaire |
| Camera (with memory card, charger, spare battery, USB cable) | | Any other awareness materials, which may include: <ul style="list-style-type: none"> • PVVP troubleshooting poster • SMS-gateway poster • 1 set of administration books (consists of 5 books) for VMT |
| Spare memory sticks (flash-disks) | | Stencils for site code + spray paint |
| Pens and pencils | | |
| Sturdy backpack | | |

3.2. Implementation Guide

1. Read the *Inspection Guide for PVVP* (this document).
2. Obtain an introductory letter (laminated to prevent damage) from the authority requesting the inspection, in order to ensure that the inspection teams have the mandate to carry out the site inspections. This introductory letter must be carried by the inspectors at all times.
3. Ensure that local authorities (Dinas/Pemda, village chief, and village management team/VMT) on site had been contacted and informed prior to departing for the sites.
4. Report to the local authority office when arriving in the area. As a minimum, this is a courtesy visit, while as a maximum, a local authority representative might accompany the inspection team.
5. Prepare all equipment (see Section 3.1) in advance before leaving the Coordination Office.
 - Keep all logistics in the car or lodging.
 - Carry equipment and supporting tools only one set per single site visit.
6. Buy spray-paint in the capital town.
7. Get info for Coordination Office where to collect documentation delivered via courier.
8. Make sure all electronic devices are fully charged at night before each site visit.
9. Travel to the site as early as possible in the morning ideally accompanied by the local authorities.
10. If you cannot find the site after maximum half day, please contact to head office for further instruction and decision.

11. Spray-paint the site code on the powerhouse door or wall using the provided stencils.
12. Allocate time wisely within 2-day visit to conduct: component compliance, performance verification, workmanship quality, on-site PVVP operator(s) training, KPI survey (through interview with relevant respondents), VMT training and taking photographs.
13. Conduct visual inspection of the civil structure and power house.
14. Conduct technical checks together with the operator. Let the operator do the check/measurements with inspector's guidance and supervision.
15. Do not adjust the system! If you see something is wrong, make notes, but do not attempt to fix or alter the system in any way.
16. Take numerous photos (see guidance in Chapter 4).
17. Conduct KPI survey based on the following components:
 - Interview and train the operator (KPI Part D)
 - Interview the VMT members (KPI Part A, B and C)
 - Interview the village chief or the most respected person related to village regulation
18. Ensure all parts of checklists, forms, and questionnaires are completed and all photos are taken BEFORE leaving the site.
19. Soon after you arrive at your lodging, type down the result to electronic format (Word document).
20. Send the electronic version to the Coordination Office via email once you have internet connection.
 - Coordination Office supervisor:
 - Email:
 - Mobile:
21. Send hard copies of checklists, forms, and questionnaires and uncompressed photos on a flash disk to the Coordination Office via courier as soon as possible.
 - Coordination Office physical address:
 - Coordination Office postal address:
 - Email:
 - Mobile:
22. Contact Coordination Office each morning (email or mobile/SMS) to communicate inspection status/problems and further proceedings.



Figure 2 EnDev site identification

All EnDev-supported sites are allocated a unique site code for easy future identification. The site code is spray painted to the powerhouse door or wall.

3.3. Inspection Process

The inspection process follows the flow as shown in Figure 3 Inspection flow diagram. In some instances, depending on the situation on site, the order of activities might be certainly modified.




Figure 3 Inspection flow diagram

3.4. General Tips

Introductory pitch: Formulate a very brief 5 sentence statement that you learn off by heart as means of quickly introducing yourself to community members. This statement, or “pitch”, ensures that you are consistent in your message and avoids you struggling for words. An example would be:

“Good morning. My name is I am here on behalf of I was sent here to do a technical inspection of the PVVP installation and to provide this/your community with information on how best to take care of and manage this technology. Maybe you have some time so that I can ask you some questions? This will help me to understand your community better.”

Listen: Avoid offering advice and opinions, unless asked for them. Allow the community to express their observations, experiences by listening attentively. Ask clarifying questions and acknowledge the communities concerns seriously.

Detach: You are there for a very specific task. Do not get too distracted by side issues. Do not make any promises to the community, unless you yourself can keep them. Some communities might experience frustrations and share these with you. This demonstrates trust and respect for you. Be very cautious though and do not get involved. Remain detached, but friendly and sympathetic.

Respect: You are a stranger entering people’s village and homes. Do not assume that they appreciate your presence. Always introduce yourself (see “pitch”) and always ask permission before asking questions and taking photographs.

Buy from a local shop: Buy a drink or a snack, even if you might not need it. This sends a signal of inclusivity. It also offers an opportunity for ice breaking and small talk.

3.5. PVVP DC System




Figure 4 Block diagram of PVVP DC system

3.5. PVVP AC System




Figure 5 Block diagram of PVVP AC system

4. Technical and Workmanship Checklist

The checklists described in this chapter, along with their corresponding templates, were originally designed during the *DGNREEC PVVP Technical Review*. Several adjustments and refinements were subsequently done as a result of lessons learnt during the inspection and evaluation processes. This Inspection Guide reflects the version as of October 2013.

Before conducting the inspection and recording the findings fill in the site code, village name and date on all pages of the checklists and questionnaires.

4.1. Component Compliance

The component compliance part of PVVP Technical Checklist is a document comprising main components of the PVVP. This checklist is used to verify actually installed components at site against the contractual obligations as specified in the contract. This checklist thus requires a pre-review of the tender/contract document and adding the relevant technical specifications into the checklist template. The template is included in **Appendix 1 Technical checklist: component compliance** and specifications from the *DGNREEC PVVP Technical Review* are inserted as examples.

In the case of the *DGNREEC PVVP Technical Review*, the component compliance covered the technical specifications for:

| |
|---|
| 1. Works conclusion |
| 2. PV modules |
| 3. PV array support |
| 4. Grid inverter |
| 5. Solar charge controller |
| 6. Battery system |
| 7. Battery inverters |
| 8. Remote monitoring system |
| 9. Power house |
| 10. Power cables and grounding |
| 11. Power house distribution panel |
| 12. Distribution, connection and household installation |
| 13. Streetlights |
| 14. Sub-subsystem of household installation |
| 15. Energy limiter - household |
| 16. LED lamp - household |
| 17. Lightning protection |
| 18. TV and digital parabola |
| 19. Commissioning and training |

| Inspection Tips | |
|-----------------|---|
| General | <ul style="list-style-type: none"> ▪ Make sure the column “Specification” has been filled-in in advance (before leaving Coordination Office). ▪ Fill in the date, name of surveyor and signature. ▪ Take photos (see Chapter 4.4). |

| | |
|--------------------------|---|
| Completing the checklist | <ul style="list-style-type: none"> ▪ For some selected technical specifications, the brand, type, etc is filled in as ideally displayed on product labels. ▪ For most specifications, only the compliance needs to be verified with “Yes” (compliance) or “No” (non-compliance) by ticking (✓) the corresponding cell. ▪ Space is provided for “comments”. Always provide “comments where “No” (non-compliance) is ticked as these greatly assist further evaluation. |
|--------------------------|---|




4.2. Performance Verification

Verification of reliable system performance is essential and should be part of the final acceptance of the system. Performance verification is a very good indicator to demonstrate whether a system is functioning optimally and all components are installed and configured correctly. It is thus the combination of component quality and workmanship quality.

In the case of the *DGNREEC PVVP Technical Review*, the performance verification recorded electrical data of spot measurements to determine performance of key components, and the template is attached as **Appendix 2** Performance verification covered:

| |
|---|
| 1. Time and weather conditions |
| 2. PV performance |
| 3. Charge controller recording |
| 4. Battery status |
| 5. Inverter performance |
| 6. Total energy production |
| 7. Remote monitoring system and pyranometer |
| 8. Streetlights |
| 9. Household connection |
| 10. Distribution grid performance |


| Inspection Tips | |
|--------------------------------------|--|
| General | <ul style="list-style-type: none"> ▪ Fill in the site code, village name, name of contractor, date, name of inspector and sign. ▪ Measurements (and opening of cabinets) shall ideally be carried out by the local operator, with guidance and supervision by the inspector. ▪ “Handheld measuring devices” refers to clamp meters, multi-meters and thermometers that the inspector carries along to site. ▪ “RMS/LCD” refers to monitoring displays installed at site. These could include the liquid crystal display (LCD) on inverters and charge controllers and/or the monitoring interface on a computer display for a remote monitoring system (RMS). ▪ Make comments on any faults or irregularities noticed. ▪ Take photos (see Chapter 4.4) of measurement displays. ▪ Ask operator to provide name, contact number and signature after measurement. |
| “Time and weather conditions” | <ul style="list-style-type: none"> ▪ “Time and weather conditions” are recorded at time of measurement as these parameters influence subsequent measurements. ▪ Time is filled in using <i>hh:mm</i> format, while the weather condition is ticked (✓) in the appropriate cell. |

| | |
|---|---|
| | <ul style="list-style-type: none"> Only the morning times are recorded, since evening measurements are not generally affected by weather conditions (in the case of PVVP).  |
| <p>“PV performance”</p> | <ul style="list-style-type: none"> “PV performance” is measured using a handheld measuring device in order to detect any deviations in electricity generation from the different solar PV module strings. The points of measurement are the different “Combiner Boxes”, using handheld measuring device. Wait for stable light conditions until you take measurements per box. Do measurements in the morning (around 10:00 to 12:00) in order to have good light conditions, and to avoid a situation where the charge controller is switching off or regulating down the power of the panels because of full batteries. Note: Each solar panel has two Voltage values (Vmp/Voltage at Maximum Power and Voc/Voltage at Open Circuit), while each solar charge controller has a voltage limit (typically 150-250VDC). Panels connected together in strings should not exceed Vmp and Voc limits of the solar charge controllers (e.g. if a panel produces 36VDC for Voc and the solar charge controller has a limit of 150VDC for Voc input, then only 4 panels can be strung together, producing 144VDC max). Measure the Voltage (V) between the positive and negative busbar in the combiner boxes. Measure the Current (Amp) with 3 or 4 strings together in order to see if the current of all strings are similar and note the values (number of strings measured and the Ampere). In case of different string currents, try to identify reasons (shading of modules, loose cables) and make comment. Be aware that when the light is changing rapidly due to clouds, the current will also change rapidly. If one or more strings have no current please check for broken, burnt or loose cables, broken panels or other irregularities and make comments.  |
| <p>“Charge controller recording”</p> | <ul style="list-style-type: none"> “Charge controller recording” records the accumulated solar energy production (kWh) since start of operation and the current charging voltage (VDC) from the solar PV array. Points of reading are all charge controllers, through LCD on charge controller (or inverter or RMS if charge controller does not incorporate LCD). Recording time is during peak electricity generation (at 10:00 to 12:00 in the case of solar PV).  |

- “Energy generated”, when compared with date of commissioning (from KPI survey) and hence the theoretically maximum available sunshine hours, allows an assessment of the availability factor of the installation.
- “Energy generated”, when compared with “total consumed energy” recording, allows an assessment of the balance between electricity generation and demand.
- “Solar PV voltage” (input to charge controller), when compared to “Measured Voltage on busbar” (output from PV) values, allows an assessment of losses between solar PV array and charge controllers. This might be indicative of the wiring quality.


“Battery status”





- “Battery status” measures the current state-of-charge of the battery as a means to gauge battery “health” and balance between electricity generation and demand.
- The point of measurement for voltage (VDC) and discharge current (Amp) is the main battery terminal, using a handheld measuring device and the reading on the Charge Controller LCD or RMS. Both values are recorded in the checklist.
- Evening measurement: first battery measurement is done after sunset, or when no electricity is generated, and during time of peak load. Around 19:00 for a PVVP installation is likely optimal. This ensures values are not corrupted, caused by simultaneous charging of batteries.
- Morning measurement: second battery measurement is done the following morning, while sun intensity is still low. Around 07:00 for a PVVP installation is likely optimal. This value, compared with the evening record, allows for an assessment of the night time load.
- The point of measurement for battery room temperature (°C) is a thermometer or sensor placed between batteries in the battery bank during hot time of day (11:00 to 14:00). This allows an assessment whether high temperatures prevail in the battery room, which will reduce battery life expectancy.
- To check whether any batteries emit more heat than others, simply touch all batteries briefly. If any hot battery cells are detected, tick (✓) the cell. This is indicative that some batteries might have a high internal resistance.



“Inverter performance”

- “Inverter performance” measures and records the AC voltage (compared to nominal 220V or 230V), the current (Amp) being drawn at time of measurement (i.e. the load) and the total supplied energy (kWh) since installation.
- Point of measurement is the AC Distribution Board busbar using handheld measurement device.
- Point of recording is the LCD on each inverter using the menu or navigation feature.
- Time of measurement and reading is evening (about 19:00 to 20:00) during peak demand and morning (about 07:00 to 08:00) during off-peak demand.
- Note: AC Distribution busbar Voltage and current measurement will likely be same for all inverters (regardless of whether all inverters is working or not). Only comparing the busbar Voltage and current with the recorded Voltage and Current from LCD or RMS will show inverter faults.



| | |
|---|---|
| | <ul style="list-style-type: none"> Record total supplied energy (kWh) at the kWh-meter(s) and/or LCD and/or RMS in the evening and the following morning. This shows approximate night-time load |
| <p>“Total energy production”</p> | <ul style="list-style-type: none"> “Total energy production” takes a reading of the one (1) or more energy meters installed at numerous time intervals. This allows for comparison of day and night time loads/consumption, but also possible variations in the meters  |
| <p>“Remote Monitoring System and Pyranometer”</p> | <ul style="list-style-type: none"> This is a simple verification that the systems are installed and operating Important: download any data stored on the devices for future analysis |
| <p>“Streetlights”</p> | <ul style="list-style-type: none"> “Streetlights” confirm installed wattage of streetlights and the daily lighting duration (either checking for an installed timer or asking the operator) Time of assessing streetlights operating is evening (after 19:00) for a general visual inspection. Operator can also provide information (verify some examples).  |
| <p>“Household connection”</p> | <ul style="list-style-type: none"> “Household connection” does spot check review on some household installations. Visually check the energy limiters and micro-circuit breakers installed at household level and records basic information Record any breakages through information from operator (and verify some examples)  |
| <p>“Distribution grid performance”</p> | <ul style="list-style-type: none"> “Distribution grid performance” measures the voltage drop between power house and furthest household and furthest social institutions (community centre, clinic or other). Point of measurement is the household wiring (or connection box) at the household with the longest cable distance from the powerhouse (i.e. the longest stretch of AC distribution cable).  |


4.3. Workmanship Quality

Quality of workmanship has a direct influence on system performance and sustainability, and poor workmanship can compromise even the best system components. The purpose is to assess whether quality of installation adheres to best practices, safety requirements and overall installation sustainability. In the case of the *DGNREEC PVVP Technical Review*, the workmanship checklist comprises various workmanship indicators clustered into different categories. The workmanship checklist is included under **Appendix 3** Workmanship checklist.

| Inspection Tips | |
|---|--|
| General | <ul style="list-style-type: none"> ▪ Fill in the date, name of surveyor and signature. ▪ Check each indicator and tick (✓) with “True” or “False”. Note that an indicator marked with “True” shows that the indicator statement (e.g. “cracked glass of PV panels”) applies and that there is indeed poor workmanship. ▪ For indicators marked “True”, provide additional comments and information. This will show whether it is an isolated minor problem or an extensive major problem. ▪ Categories 5a), 5b), 5c), 8, 13, 15 and 18 are highlighted in RED in the checklist. This is because “True” indicators in these categories might pose a danger or safety risk to persons. Inspectors shall alert the operator to these dangers. ▪ Take photos of all indicators (regardless of “True” or “False”). ▪ For streetlights: check operational status during the evening to determine broken streetlights. ▪ For households: only spot check at 3-6 houses. |
| <ol style="list-style-type: none"> 1. PV module quality 2. PV module array foundation 3. PV array mounting structure | |
| <ol style="list-style-type: none"> 4. PV array combiner box and internal wiring | |

| | | |
|---|--|--|
| <p>5. a) PV module wiring, b) External wiring weather proofing c) Wiring to power house</p> <p>6. Grounding and earthing</p> | | |
| <p>7. Battery rack</p> <p>8. Battery terminal connections</p> | | |
| <p>9. Internal powerhouse wiring</p> <p>10. Powerhouse foundation</p> <p>11. Powerhouse general condition</p> <p>12. Powerhouse ventilation</p> <p>13. Powerhouse flooding prevention</p> | | |
| <p>14. Fence and gate</p> | | |
| <p>15. Distribution grid pole installation</p> <p>16. Distribution grid wiring</p> <p>17. Streetlight installation</p> | | |

18. Household installation



4.4. Photographs

Collecting photographic evidence of the inspection on site is vital. Photographs confirm the observations of the inspector and can also reveal issues that are not recorded in the checklists and questionnaires.

| General Tips |
|--|
| <ul style="list-style-type: none"> Set the camera to produce photographs with minimum size of 3 MB or around 3 megapixels (2048x1536) in JPEG format. This is important because it allows zooming into the picture for future analysis. |
| <ul style="list-style-type: none"> Familiarise yourself with your camera. Take some practice shots at different settings of the same object and compare the results. Load practice pictures onto computer to check whether the file size is sufficient and format is correct. Be conscious of what photographs to take and how best to capture an object. Keeping in mind that others will view the photographs as well, and might not immediately notice what you wanted to show. Also take pictures that include technology and <u>people in action</u> to liven up the photograph. Be aware of opportunities to take interesting pictures, i.e. do not only stick to the picture list as included below. Try to include more than one object in the picture so that the photograph contains several messages and reveals more information. |
| <p>Camera orientation:</p> <ul style="list-style-type: none"> Take photos in landscape for wide shots (e.g. entire PV array area) Take photos in portrait for high shots (e.g. distribution pole) Take close-up photos of detailed views (e.g. to show faults or LCD display readings) |
| <p>Lighting:</p> <ul style="list-style-type: none"> Always ensure that a light source is shining onto the object. Take outside photographs with your back to the sun. Be aware that flash might cause blurry reflection, so take pictures at an angle to avoid this. Do not use flash if not necessary. It wastes battery life and can over-light to object. Do not take of an object with a brightly lit background. This will only show the silhouette of the object. |
| <p>Contrasts:</p> <ul style="list-style-type: none"> Be aware of contrasting colours around the object. Background colours that contrast with the object make the object appear clearer and better defined. This is especially true if the background is of a single colour. |
| <p>Focus:</p> <ul style="list-style-type: none"> Keep the camera steady. Blurry pictures are useless. Press the shutter button on digital camera half-way first, to allow the camera to focus. Blurry pictures are useless. |
| <p>Dimensions:</p> <ul style="list-style-type: none"> Use familiar objects or people to indicate size of the object. |

Framing:

- Centre the object to ensure it is not cut in the picture.
- Avoid irrelevant side objects in the picture.
- Use different angles to take picture of an object to ensure that the picture clearly shows certain details.

The section below shows some examples of good and bad inspection photos. Photos with captions in green-font are the good examples, while captions in red-font are examples of the bad ones.

Good and bad of inspection photo



People in action, showing clearly what they are doing, liven up a photograph and make it more interesting.



Picture with more than one “object” (in this case: poor wiring, corrosion on steel frame, no conduits and bolts not equal length) reveal more information.



Close-up picture of measurement reading, BUT flash causes reflection, which covers numbers.



Picture taken too close, cutting off both person and technology. The context of the picture is compromised.



Good overview picture, BUT solar panels cut off. Slight increase of camera distance would have been better.



Object is not centred, with very poor focus and lighting, and several cut offs in the picture. The picture has very little information value.



Very interesting picture showing a home-made streetlight, with a standard streetlight, BUT the car behind the solar panels is disturbing.



Picture out of focus, too low picture resolution (only 90kB), too close and wrong angle. Angle from below, taken from opposite direction (i.e. showing underside of panels and unsealed conduit opening) would have been better.



Good picture of general interest, showing logistical challenges in reaching site. Main object (road) well-centred, with motorcycle as reference. Without motorcycle this picture would have less meaning.



Clear close-up picture with size reference (photographer's hand).



Main object (batteries) very well centred in the picture with correct orientation. Good lighting, sharp focus and picture shows other objects (ventilation openings, neat battery room, conduits).



Picture with too much backlight and wrong orientation (landscape orientation from slightly greater distance would show ground conduits and avoid backlight).

The photograph checklist is presented below.

Table 2 List of photographs

| List of photographs to take | | |
|-----------------------------|---------------------------------|---|
| 1 | First page of KPI questionnaire | This is the first photo should be taken (make sure the site code is written as it may help identifying what photos belong to what site) |
| 2 | Outside power house | <ul style="list-style-type: none"> ▪ Highlight the distance to the solar array ▪ Foundation and apron condition ▪ General workmanship (i.e. plastering, painting) |
| 3 | Inside power house | <ul style="list-style-type: none"> ▪ Overview of power house (with battery, inverter, and monitoring system visible) ▪ Overview of general condition (cleanliness, tidiness) ▪ Overview of ventilation ▪ Detail of windows and ventilation (glass and insect screen installed?) |
| 4 | Battery | <ul style="list-style-type: none"> ▪ Plate showing brand and type ▪ Arrangement of batteries ▪ Battery terminal connection ▪ Measurement of battery room temperature |
| 5 | Charge controllers | <ul style="list-style-type: none"> ▪ Plate showing brand and type ▪ General workmanship ▪ Controller interior |
| 6 | Inverter | <ul style="list-style-type: none"> ▪ Plate showing brand and type ▪ General workmanship ▪ Measurements as shown on LCD |
| 7 | Details of cabling | It comprises both external and internal cabling, to highlight if the correct cables (in |

| | | |
|-------------------------------------|--|---|
| | | terms of type and size) are used as well as the quality of installation |
| 8 | Solar array | <ul style="list-style-type: none"> ▪ Overview of solar array (TIP: take a higher land or climb the lightning rod to get the overall picture of the site, if possible) ▪ Foundation and struts ▪ Grounding ▪ Mounting (nuts and bolts) |
| 9 | Solar module | <ul style="list-style-type: none"> ▪ Plate showing brand and type ▪ Junction box ▪ Randomly on some spots, be alert for damage/breakage! |
| 10 | Remote monitoring system (RMS) | <ul style="list-style-type: none"> ▪ Location of computer set in the power house ▪ Display of monitoring software on screen |
| 11 | Connection and distribution box in the power house or in the panel box | <ul style="list-style-type: none"> ▪ Ampere and Voltage measurement ▪ kWh-meter and hour-meter records |
| 12 | Existed administration books (if any) | With number of customers/household visible |
| 13 | Distribution pole and cables | <ul style="list-style-type: none"> ▪ State of poles (showing distance between poles) ▪ State of cables |
| 14 | Streetlights | <ul style="list-style-type: none"> ▪ Type of lamp and fixture (close-up) ▪ Installation and location |
| 15 | Energy limiter | <ul style="list-style-type: none"> ▪ Close-up photo of energy limiter and its installation ▪ Overview showing where it is located in a house |
| 16 | Public television | Overview showing where it is located |
| 17 | HH connection | <ul style="list-style-type: none"> ▪ Close-up of socket/plug and switch ▪ Close-up of lamps ▪ Cabling workmanship ▪ Overview of connection workmanship |
| 18 | People in actions | <p>For example:</p> <ul style="list-style-type: none"> ▪ Operator cleaning the PV module ▪ Inspector checking the installation ▪ Inspector training the operator ▪ Sensitization (sosialisasi) of VMT and villagers |
| 19 | Surroundings of system | <ul style="list-style-type: none"> ▪ Pathway to the power house ▪ Surrounding trees ▪ Fence and gate workmanship |
| 20 | Access road to the village | <ul style="list-style-type: none"> ▪ Road condition ▪ Mode of transportation used ▪ Overview of village |
| 21 | Site overview | Shows the entire installation taken from a distance |
| 22 | Village chief (when agreed upon) | Ask kindly the village chief to be photographed |
| 23 | Detail photo if any installation looks wrong or unsure | Be observant and critical! |
| Photograph naming and filing | | |
| 1 | Create individual folder for each site | Name the folder according to the site code with this format: ProvinceSXX , example: JaTimS01, MalS02, PapBarS12 |
| 2 | General file and folder naming | Suitable folder naming should be designed and agreed prior to reporting. As a minimum, a filename should contain site code and component item. |

5. KPI Questionnaire

The Key Performance Indicator (KPI) survey is conducted using a questionnaire and collects technical, social, economic, and environmental data. The data are vital as a baseline status of the PVVP installation, allowing for future comparison after subsequent surveys. The KPI survey was originally designed for capturing data on micro-hydro power (MHP) installations and has been used extensively by EnDev Indonesia since mid-2012 and comprises five main sections:

- Part A: General information
- Part B: Key performance indicators in target area
- Part C: Administration and management
- Part D: Operation and management

The KPI questionnaire considered several aspects during design, which include:

- a. The question wording being simple enough to be understood by unskilled surveyor and asked to rural people.
- b. The questions are arranged in logical order and working flow so that unskilled surveyor can naturally converse with the interviewee and complete all questions smoothly.
- c. Tick boxes are used extensively. The advantages are: a) minimize narrative answers by pre-defining multiple answers beforehand, b) occurrence and frequency of set answers are more easily quantified (while unanticipated reasons can be addressed through “other” option), and c) easier to handle conditional questions effectively.
- d. The question arrangement accommodates consistency verification of data surveyed.
- e. Anticipating most common and typical situation in the village that might potentially disturb survey processes and data integrity.
- f. The questionnaire format must be flexible enough to allow for adjustments and customizations, depending on the technology deployed at site.



Figure 6 KPI survey

In many cases KPI surveys comprise group interviews with members of the Village Management Team.

In order to help field surveyors to conduct the KPI Survey, a questionnaire manual was also compiled.

The KPI survey adjusted for the *DGNREEC PVVP Technical Review* is included in **Appendix 4** along with a detailed user manual in **Appendix 5**.

6. Technical Summary Sheet

The Technical Summary sheet is completed by an expert evaluator and/or a highly experienced PVVP inspector.

The expert evaluator needs to have extensive experience and expertise regarding off-grid electrification systems and the deployed technology (photovoltaic [PV] mini-grids in the case of the *DGNREEC PVVP Technical Review*). Naturally the evaluation can only be done well if the aforementioned checklists are thoroughly completed and numerous photographs are available.

The technical summary sheet is a resume of findings collected and concluded from the technical and workmanship checklist. It consists of 4 parts as follows:

- Part 1: Component compliance as verification between contract requirements and actual site installation. This part presented into 6 categories: solar module, inverter, charge controller, battery system, balance of system, and appliances.
- Part 2: Measurements to give insight of technical performance and electrical status of the system. This part is presented into 4 categories: PV module output consistency, battery storage acceptable, AC distribution board voltage acceptable, and distribution grid voltage acceptable.
- Part 3: Workmanship verification as a review of workmanship as per general quality, health and safety requirements.
- Part 4: Recommendations regarding any possible follow-up with contractor.
- Part 5: Pictures of poor quality workmanship as per 20-point “workmanship quality” checklist

Evaluation of Part 3 Workmanship is done according to a scoring system using a rating of 5 to 1 (best to worst):

- 5 = very good, meets required specification
- 4 = good, meets required specification with few faults
- 3 = fair, meets required specifications with several faults
- 2 = poor, below standard, some major faults
- 1 = safety risk, serious faults and shortcomings

Summarised workmanship scorings per PVVP site are converted into a percentage (%) serving to compare the scorings between different sites and different contractors. A contractor achieving a scoring of five (5) for each of the 20 workmanship categories would thus score 100% (complete success). The lowest possible score would be 20% (complete failure).

For any workmanship score of 1 and/or 2 the evaluator must include photographic evidence into the Summary Sheet.

The Technical Survey Summary template with its scoring guidance is included in **Appendix 6**.

APPENDIX

Appendix 1 Technical checklist: component compliance

| PVVP Technical Checklist - Component Compliance (version 150615) | | | | | | | |
|--|--|---|----------|----------------------------|-----|----|---------|
| SITE CODE: <input type="text"/> | | INSPECTOR: <input type="text"/> | | DATE: <input type="text"/> | | | |
| VILLAGE/HAMLET: <input type="text"/> | | CONTRACTOR: <input type="text"/> | | | | | |
| CAPACITY: <input type="text"/> | | SIGNATURE: <input type="text"/> | | | | | |
| NO | COMPONENT | SPECIFICATION FROM CONTRACT | Qty/Size | Unit | Yes | No | REMARKS |
| 1.0 | WORK CONCLUSION | | | | | | |
| 1.1 | Clean up location / work site | | 1 | ls | | | |
| | NOTES: | | | | | | |
| 2.0 | SOLAR MODULES | | | | | | |
| 2.1 | Solar modules and its properties already on location | | | pc | | | |
| 2.2 | Solar modules are installed on its frame | | | ls | | | |
| 2.3 | Total capacity solar array (record in kWp) | | | kWp | | | |
| 2.4 | Solar module size (Wp per module) | | | Wp | | | |
| 2.5 | Type of solar module (mono/polycrystalline) | | | | | | |
| 2.6 | Brand of solar module | | | | | | |
| 2.7 | Model of solar module | | | | | | |
| | NOTES: | | | | | | |
| 3.0 | PV ARRAY SUPPORT | | | | | | |
| 3.1 | Solar modules foundation structure | | 1 | ls | | | |
| 3.2 | Frame material | galvanized iron/metal through hot deep galvanized treatment | | | | | |
| 3.3 | Module support | free standing above foundation | | yes/no | | | |
| 3.4 | Foundation | concrete | | | | | |
| 3.5 | Mounting angle | between 10-15 degrees to ground level | | yes/no | | | |
| 3.6 | Orientation | facing the equator | | | | | |
| | NOTES: | | | | | | |
| 4.0 | GRID INVERTERS (applicable only to AC Bus system types) | | | | | | |
| 4.1 | Grid (solar) inverters already on location | | | pc | | | |
| 4.2 | Grid inverters are installed | | | pc | | | |
| 4.3 | Grid inverter size (kW / kVA) | | | kWp | | | |
| 4.4 | Type of grid inverter (pure or modified sine wave) | | | | | | |
| 4.5 | Brand of grid inverter | | | | | | |
| 4.6 | Model of grid inverter | | | | | | |
| | NOTES: | | | | | | |

| NO | COMPONENT | SPECIFICATION FROM CONTRACT | Qty/Size | Unit | Yes | No | REMARKS |
|------------|--|-----------------------------|----------|-------|-----|----|----------|
| 5.0 | SOLAR CHARGE CONTROLLER (SCR) | | | | | | |
| 4.1 | Solar charge controllers already on location | | | pc | | | Comment: |
| 4.2 | Solar charge controllers are installed | | | pc | | | |
| 4.3 | Solar charge controller (kW / kVA) | | | kWp | | | |
| 4.4 | Model of solar charge controller | | | | | | |
| 4.5 | Type of solar charge controller (MPPT or not) | | | | | | |
| 4.6 | Brand of solar charge controller | | | | | | |
| | NOTES: | | | | | | |
| | | | | | | | |
| 6.0 | BATTERY SYSTEM | | | | | | |
| 6.1 | Batteries and its Properties already on location | | | pc | | | Comment: |
| 6.2 | Batteries are installed | | | ls | | | |
| 6.3 | Brand of battery | | | | | | |
| 6.4 | Type of battery | | | | | | |
| 6.5 | Nominal capacity (volts per cell) | | | Volts | | | |
| 6.6 | Battery capacity/cell (Ah) | | | Ah | | | |
| | NOTES: | | | | | | |
| | | | | | | | |
| 7.0 | BATTERY INVERTERS | | | | | | |
| 7.1 | Battery inverters already on location | | 0 | pc | | | Comment: |
| 7.2 | Battery inverters are installed | | 1 | pc | | | |
| 7.3 | Battery inverter size (kW / kVA) | | 5 | kWp | | | |
| 7.4 | Type of grid inverter (pure or modified sine wave) | | | | | | |
| 7.5 | Brand of inverter | | | | | | |
| 7.6 | Model of inverter | | | | | | |
| | NOTES: | | | | | | |
| | | | | | | | |
| 8.0 | REMOTE MONITORING SYSTEM | | | | | | |
| 8.1 | Remote monitoring system already on location | | 1 | set | | | Comment: |
| 8.2 | Remote monitoring is installed | | 1 | ls | | | |
| 8.3 | Data connection model (Webbox/Leonics/Schneider) | | | set | | | |
| 8.4 | Data storage - memory type | | | | | | |
| 8.5 | Data storage - memory size | | | MB | | | |
| 8.6 | Pyranometer brand and model | | | | | | |
| 8.7 | Pyranometer data logger brand and model | | | | | | |
| 8.8 | External Memory on additional data logger | | | | | | |
| | NOTES: | | | | | | |
| | | | | | | | |

| NO | COMPONENT | SPECIFICATION FROM CONTRACT | Qty/Size | Unit | Yes | No | REMARKS |
|--|--|---|----------|------|-----|----|----------|
| 9.0 POWER HOUSE | | | | | | | |
| 9.1 | Power House is done | | 1 | ls | | | Comment: |
| 9.2 | Type (permanent house/shelter) | | | | | | |
| 9.3 | Shelter / building material (polyurethane and mild steel or brick) | | | | | | |
| 9.4 | Room size | | | m2 | | | |
| 9.5 | Walls (bricks or equal, neatly plastered and painted) | | | | | | |
| 9.6 | Door (board/aluminum and equipped with lock) | | | | | | |
| 9.7 | Floor (ceramics) | | | | | | |
| 9.8 | Footpath (concrete or using con-block with 1 meter minimum width) | | | | | | |
| 9.9 | Electricity installation for power house | 5 points (3 lamps, 2 sockets), MCB 2 A | | | | | |
| 9.10 | Equipped surrounding with lightning rod system | | | | | | |
| 9.11 | BRC fence is installed | | 1 | ls | | | |
| 9.12 | Fence periphery | BRC type 120cm minimum height equipped with gate | | | | | |
| NOTES: | | | | | | | |
| | | | | | | | |
| 10.0 POWER CABLES AND GROUNDING | | | | | | | |
| 10.1 | Power cable from battery to inverter and/or battery to solar charge controller | minimum 1x70 mm2 (SPLN/SNI) to each string | | | | | Comment: |
| 10.2 | Power cable from inverter to distribution panel | type NYY 4 x 50 mm2 (SPLN/SNI) | | | | | |
| NOTES: | | | | | | | |
| | | | | | | | |
| 11.0 POWER HOUSE DISTRIBUTION PANEL | | | | | | | |
| 11.1 | Distribution panels already on location | | | set | | | Comment: |
| 11.2 | Distribution panels are installed | | | ls | | | |
| 11.3 | Power capacity | | | kVA | | | |
| 11.4 | Number of feeder breakers | | | sets | | | |
| 11.5 | System voltage 220 or 230 VAC | | | VAC | | | |
| 11.6 | Monitoring device installed (volt meter) | | | | | | |
| 11.7 | Monitoring device installed (current/amp meter) | | | | | | |
| 11.8 | Monitoring device installed (frequency meter) | | | | | | |
| 11.9 | Monitoring device installed (kWh meter) | | | | | | |
| 11.10 | Positioning of distribution panel | as per safety standard and easy to monitor by the operator? | | | | | |
| NOTES: | | | | | | | |
| | | | | | | | |
| 12.0 DISTRIBUTION, CONNECTION, AND HOUSEHOLD INSTALLATION | | | | | | | |
| General: | | | | | | | |
| 12.2 | Pole network already on location | | | pc | | | Comment: |
| 12.3 | Network cabling for low voltage already on location | | | m | | | |
| 12.4 | Network cabling for medium voltage already on location | | | m | | | |
| 12.5 | Medium voltage transformers installed | using air network | | pc | | | |

| NO | COMPONENT | SPECIFICATION FROM CONTRACT | Qty/Size | Unit | Yes | No | REMARKS |
|--|---|--|----------|--------|-----|----|----------|
| 12.6 | Distribution Network already on location | | | ls | | | |
| 12.7 | Type of network | using air network | | | | | |
| 12.8 | Distance between pole | maximum 40 m | | | | | |
| 12.9 | Type of poles | 7 m, PLN standard (SPLN) | | | | | |
| 12.10 | installation depth | deep-seated with 1 meter depth | | | | | |
| 12.11 | installed equipment on poles | equipped with network accessories | | | | | |
| 12.12 | Inter-poles cable | NFA 2x35 mm2 + 1x25 mm2 (SPLN) | | | | | |
| 12.13 | Cables from pole to house | NFA 2x10 mm2 (SPLN) | | | | | |
| 12.14 | Cable deflection height between poles | 4 m from ground surface | | | | | |
| NOTES: | | | | | | | |
| | | | | | | | |
| 13.0 STREETLIGHTS | | | | | | | |
| 13.1 | Number of streetlights already on location | | | pc | | | Comment: |
| 13.2 | Number of streetlights installed | | | | | | |
| 13.3 | Control cabinet in power house grounded? | | | | | | |
| NOTES: | | | | | | | |
| | | | | | | | |
| 14.0 SUB-SYSTEM OF HOUSEHOLD INSTALLATION | | | | | | | |
| 14.1 | LED Lamps already on location | | | pc | | | Comment: |
| 14.2 | Household Cabling already on location | | | m | | | |
| 14.3 | Household Installation are installed | | | pc | | | |
| 14.4 | Number of connections (households/buildings etc) | | | pc | | | |
| 14.5 | Protection system | current limiter (MCB) 1 A (including box and seal), 220 Volt | | | | | |
| 14.6 | Load per house | 4 points (3 lamps and 1 socket) | | | | | |
| NOTES: | | | | | | | |
| | | | | | | | |
| 15.0 ENERGY LIMITER - HOUSEHOLD | | | | | | | |
| 15.1 | Number of <i>Energy Limiter</i> already on location | | | pc | | | Comment: |
| 15.2 | Number of energy limiters installed | | | | | | |
| 15.3 | Input voltage | 220 VAC, single phase, 50 Hz | | | | | |
| 15.4 | Cables in house installation | NYM 3x1.5 mm2 and 2x1.5 mm2. SPLN | | | | | |
| 15.5 | Grounding system | | | yes/no | | | |
| NOTES: | | | | | | | |
| | | | | | | | |
| 16.0 LED LAMP - HOUSEHOLD | | | | | | | |
| 16.1 | Lamp type | LED | | pc | | | Comment: |
| 16.2 | Power consumption | maximum 5 W | | | | | |
| NOTES: | | | | | | | |
| | | | | | | | |

| NO | COMPONENT | SPECIFICATION FROM CONTRACT | Qty/Size | Unit | Yes | No | REMARKS |
|-------------|---|---|----------|------|-----|----|----------|
| 17.0 | LIGHTNING PROTECTION | | | | | | |
| 17.1 | Tower and wire | tri-angle, guyed wire | | | | | Comment: |
| 17.2 | Lightning arresters already on location | | | set | | | |
| 17.3 | Lightning arresters are Installed | | | set | | | |
| 17.4 | Sky counter / strike counter installed | | | each | | | |
| 17.5 | Grounding system | | | | | | |
| | NOTES: | | | | | | |
| | | | | | | | |
| 18.0 | TV AND DIGITAL PARABOLA | | | | | | |
| 18.1 | TV and antenna already on location | | | set | | | Comment: |
| 18.2 | LCD / LED TV model | 32 inch, 100-240 VAC, 50/60 Hz LED/LCD | | | | | |
| 18.3 | Digital parabola type | solid dish (rusty-free) minimum 6 feet | | | | | |
| 18.4 | Accessories | including receiver, positioned, and actuator | | | | | |
| 18.5 | Pole | Iron pole 1.5 m | | | | | |
| 18.6 | Installation | public place, strongly recommended in village hall or other public places that are accessible | | | | | |
| | NOTES: | | | | | | |
| | | | | | | | |
| 19.0 | COMMISSIONING AND TRAINING | | | | | | |
| 19.1 | Comissioning is completed | | 1 | ls | | | Comment: |
| 19.2 | Operator training is given | | 1 | ls | | | |
| 19.3 | Village Management Team training is given | | 1 | ls | | | |
| | NOTES: | | | | | | |
| | | | | | | | |

Appendix 2 Technical checklist: performance verification

| PVVP Technical Checklist - Performance Verification (version 150615) | | | | | | | | | | | | |
|--|--|------------|--|---------|-------------------|---------|---|--|-------------------|--|-----------------------|--|
| SITE CODE: | <input style="width: 95%;" type="text"/> | DATE: | <input style="width: 95%;" type="text"/> | | | | | | | | | |
| VILLAGE/HAMLET: | <input style="width: 95%;" type="text"/> | INSPECTOR: | <input style="width: 95%;" type="text"/> | | | | | | | | | |
| CONTRACTOR: | <input style="width: 95%;" type="text"/> | SIGNATURE: | <input style="width: 95%;" type="text"/> | | | | | | | | | |
| 1. Time and Weather condition (during measurement): | | | | | | | | | | | | |
| PV performance measurement - Late Morning | Time: | hh:mm | Sunny | Cloudy | Rain | | | | | | | |
| Battery status measurement - Evening (Just after dark) | Time: | hh:mm | Sunny | Cloudy | Rain | | | | | | | |
| Battery status measurement - Early Morning (before sunrise) | Time: | hh:mm | Sunny | Cloudy | Rain | | | | | | | |
| Inverter performance - Late Morning | Time: | hh:mm | Sunny | Cloudy | Rain | | | | | | | |
| 2. PV performance | | | | | | | | | | | | |
| At 10:30 - 11:00 Voltage and Current for PV string to check consistency - measure on the each combiner box - if feasible. In case of different string currents, try to identify reasons (shading modules, loose cables) and make comment Take photos of display readings | | | | | | | | | | | | |
| Combiner Box | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | Continue in new sheet | |
| Number of strings: | | | | | | | | | | | Nr | |
| Measured Voltage on busbars: | | | | | | | | | | | Volt | |
| Measure current with 3 or 4 strings together: | | | | | | | | | | | Amp | |
| Comments: | | | | | | | | | | | | |
| 3. Charge controller recording | | | | | | | | | | | | |
| Record accumulated solar energy production since start of operation (reading from LCD on charge controller, inverter or RMS) Recording at 10:00 to 12:00 during peak electricity generation | | | | | | | | | | | | |
| Charge controller | 1 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 9 | 10 | Continue in new sheet | |
| Energy generated: | | | | | | | | | | | kWh | |
| Solar PV voltage: | | | | | | | | | | | Volt | |
| Comments: | | | | | | | | | | | | |
| 4. Battery status | | | | | | | | | | | | |
| Battery measurements at evening (19.00-20:00) and morning (04:00-05:00) Has to be dark Only over all measurement - not each individual batteries Take photos of display readings (handheld measuring device, LCD and/or RMS) | | | | | | | | | | | | |
| Battery Voltage (from handheld measuring device) - Evening: | <input style="width: 95%;" type="text"/> | Volt | | | | | Battery Voltage (from handheld measuring device) - Morning: | <input style="width: 95%;" type="text"/> | Volt | | | |
| Battery Voltage (from LCD or RMS) - Evening: | <input style="width: 95%;" type="text"/> | Volt | | | | | Battery Voltage (from LCD or RMS) - Morning: | <input style="width: 95%;" type="text"/> | Volt | | | |
| Discharge Current (from handheld measuring device) - Evening: | <input style="width: 95%;" type="text"/> | Amp | | | | | Discharge Current (from handheld measuring device) - Morning: | <input style="width: 95%;" type="text"/> | Amp | | | |
| Discharge Current (from LCD or RMS) - Evening: | <input style="width: 95%;" type="text"/> | Amp | | | | | Discharge Current (from LCD or RMS) - Morning: | <input style="width: 95%;" type="text"/> | Amp | | | |
| Battery room temperature (measure point between batteries) between 11:00 and 15:00: | | | | | | | | | | <input style="width: 95%;" type="text"/> | °C | |
| Are there hot battery cells (touch by hand each cell if there are temperature differences)?: | | | | | | | | | | | | |
| <input type="checkbox"/> No <input type="checkbox"/> Yes If Yes, provide details: | | | | | | | | | | | | |
| Comments: | | | | | | | | | | | | |
| 5. Inverter performance | | | | | | | | | | | | |
| Inverter measurements at evening (19.00-20:00) and morning (07:00-08:00) Take photos of display readings (handheld measuring device, LCD and/or RMS) | | | | | | | | | | | | |
| | Inverter 1 | | Inverter 2 | | Inverter 3 | | Inverter 4 | | Inverter 5 | | | |
| | Evening | Morning | Evening | Morning | Evening | Morning | Evening | Morning | Evening | Morning | | |
| Inverter Voltage (measured with handheld device at AC distribution board): | | | | | | | | | | | Volt | |
| Inverter Current (measured with handheld device at AC distribution board): | | | | | | | | | | | Amp | |
| Inverter Voltage (reading from LCD or RMS): | | | | | | | | | | | Volt | |
| Inverter Current (reading from LCD or RMS): | | | | | | | | | | | Amp | |
| Total supplied energy since start of operation (reading from LCD or kWh-meter): | | | | | | | | | | | kWh | |
| Comments: | | | | | | | | | | | | |

| 6. Total energy production | | | | | | | | | | |
|---|------------|------------|------------|------------|------------|------------|------------|------------|------------|------------|
| Take kWh measurements throughout the time of visit Take photos of display readings (kWh Energy Meter at Plant) | | | | | | | | | | |
| | Reading 1 | Reading 2 | Reading 3 | Reading 4 | Reading 5 | Reading 6 | Reading 7 | Reading 8 | Reading 9 | Reading 10 |
| | time 00h00 |
| kWh Meter # 1 installed in AC distribution box (reading from meter or LCD or RMS): | | | | | | | | | | kWh |
| kWh Meter # 2 installed in AC distribution box (reading from meter or LCD or RMS): | | | | | | | | | | kWh |
| kWh Meter # 3 installed in AC distribution box (reading from meter or LCD or RMS): | | | | | | | | | | kWh |
| Comments: | | | | | | | | | | |

| 7. Remote Monitoring System and Pyranometer | | | | | | | |
|--|-------------------|----|-------------------|----|----------------------|----|----------------------------|
| Take photos of display readings Copy card data | | | | | | | |
| | System installed? | | System recording? | | Data copy succesful? | | Data volume of copied data |
| | Yes | No | Yes | No | Yes | No | |
| Remote Monitoring System (check PC or similar monitoring device): | | | | | | | MB |
| Pyranometer (check PC, pyranometer data logger or similar device): | | | | | | | MB |
| Comments: | | | | | | | |

| 8. Streetlights | | | |
|---|--|-------|---------------------------------------|
| Visual inspection after dark and verification with operator | | | |
| Single streetlight power demand: | | Watt | Lighting duration per day: |
| | | | hrs/day |
| Number of streetlights installed: | | units | Number of streetlights not operating: |
| | | | units |
| Comments: | | | |

| 9. Household connection | | | | | |
|--|-----|-----------|---------------------------------------|-----|-----|
| Visual inspection and verification with operator | | | | | |
| Energy limiters installed? | Yes | No | Mini Circuit Breaker (MCB) installed? | Yes | No |
| Energy limiter setting: | | Watts/day | Mini Circuit Breaker (MCB) rating: | | Amp |
| Number of energy limiters installed: | | units | | | |
| Number of energy limiters not operating: | | units | | | |
| Comments: | | | | | |

| 10. Distribution grid performance | | |
|---|--|------|
| Measurement at furthest household from power house (i.e.with longest grid cable connection) at evening (19:00-20:00) Measurement at furthest social institution at evening (19:00-20:00) Take photos of display readings (of handheld measuring device) | | |
| Measure Voltage at furthest social institution: | | Volt |
| Measure Voltage at furthest household: | | Volt |
| Comments: | | |

Appendix 3 Workmanship checklist

| PVVP Technical Checklist - Workmanship Quality (version 150615) | | | | |
|---|--|------|-------|---------------------|
| Category | Indicator | TRUE | FALSE | How many?/Comments? |
| 1. PV module quality: | 1 Cracked glass of PV panels? | | | |
| | 2 Twisted or broken PV panel frames? | | | |
| | 3 White or brown spots under the glass? | | | |
| | 4 Bubbles of air or moisture behind the glass? | | | |
| | 5 Broken back sheeting (white EVA)? | | | |
| | 6 Loose foils (delamination) at backside? | | | |
| | 7 Browning under glass? | | | |
| | 8 Junction boxes at backside loose or without cover? | | | |
| | 9 Solar panels are partially shaded during the day? | | | |
| | 10 Damaged cables from animals? | | | |
| 2. PV module array foundation: | 1 Broken or cracked concrete blocks? | | | |
| | 2 Poor concrete mixture? | | | |
| | 3 Insufficient foundation depth? | | | |
| | 4 Anchor bolts too close to foundation edge or foundation too small? | | | |
| | 5 Vulnerable to land slide? | | | |
| 3. PV array mounting structure: | 1 Overall array structure twisted or imbalanced? | | | |
| | 2 PV module aluminium frames touch galvanised steel structure? | | | |
| | 3 Height between lowest module and ground surface insufficient? | | | |
| | 4 Distance between PV arrays too small? | | | |
| | 5 Bad or loose panel clamps? | | | |
| | 6 Loose anchor bolts into foundation? | | | |
| | 7 Bad galvanizing on steel structure? | | | |
| | 8 Insufficient support struts / cross members? | | | |
| | 9 Rusting at structure or bolts? | | | |
| 4. PV array combiner box and internal wiring: | 1 Casing or housing is cracked? | | | |
| | 2 No rain cover? | | | |
| | 3 No rubber seals around door? | | | |
| | 4 Mounted not correctly? | | | |
| | 5 No lock or not lockable? | | | |
| | 6 Door is not closing properly? | | | |
| | 7 Water found inside the box? | | | |
| | 8 Broken or burnt components inside? | | | |
| | 9 Loose cable clamps inside? | | | |
| | 10 Unbundled and disorganised cable layout? | | | |
| | 11 Unsecure/unfirm connections or connectors? | | | |
| | 12 Animals inside (or signs of animal like ants or mouse)? | | | |
| 5. a) PV module wiring | 1 Loose hanging cables between PV modules? | | | |
| | 2 Cable conduits under PV modules not used? | | | |
| | 3 Unsecure/unfirm connections or connectors? | | | |
| | 4 Plug in connector socket missing? | | | |
| | 5 Unsecure/unfirm junction box? | | | |
| | 6 Burnt cables or connectors? | | | |
| | 7 Wrong cable dimension used? | | | |
| 5. b) External wiring weather proofing: | 1 Any external cables exposed to direct sunlight or rain? | | | |
| | 2 Any external cables with exposed copper wire? | | | |
| | 3 Any external cables connections vulnerable to water entry? | | | |
| | 4 Cable entries and exits not sealed with glands? | | | |
| | 5 Cable conduits not sealed? | | | |
| 5. c) Wiring to power house | 1 Conduits not used properly from combiner box to power house? | | | |
| | 2 Cables vulnerable to physical damage? | | | |
| | 3 Cable entry point at power house wall not sealed? | | | |
| | 4 Cables/conduits to power house not mounted securely? | | | |

| Category | Indicator | TRUE | FALSE | How many?/Comments? |
|---|--|------|-------|---------------------|
| 6. Grounding and earthing: | 1 No earthing of PV array structure? | | | |
| | 2 No earthing of combiner box? | | | |
| | 3 No earthing through lightning protection? | | | |
| | 4 No earthing at charge controller? | | | |
| | 5 No earthing at battery charger? | | | |
| | 6 No earthing at inverter? | | | |
| | 7 No earthing of battery protection box? | | | |
| | 8 No earthing of AC distribution box | | | |
| | 9 No earthing at all households? | | | |
| | 10 No grounding connection in grounding pit/grounding rod? | | | |
| | 11 Lightning mast not secure and unstable? | | | |
| | 12 Wrong cable type/colour used? | | | |
| 7. Battery rack: | 1 Unstable battery rack? | | | |
| | 2 Not strong enough? Risk of collapse? | | | |
| | 3 Signs of corrosion or rust? | | | |
| | 4 Signs of leaking batteries? | | | |
| | 5 Wood or plastic pallet used? | | | |
| | 6 No side bars to prevent batteries falling? | | | |
| 8. Battery terminal connections: | 1 No insulation around battery-to-battery cables? | | | |
| | 2 Exposed battery terminals? | | | |
| | 3 Exposed main battery bank combiner terminal? | | | |
| | 4 Incorrect battery connections? | | | |
| | 5 Main cables exposed to physical damage? | | | |
| | 6 Signs of sulfide flakes at terminals? | | | |
| | 7 Battery protection box fuses insufficient? | | | |
| | 8 Battery protection box wiring insufficient? | | | |
| 9. Internal power house wiring: | 1 No conduits or cable trenches used? | | | |
| | 2 No glands used at any cable entry points? | | | |
| | 3 Unbundled and disorganised cable layout? | | | |
| | 4 Cables with exposed copper wire? | | | |
| | 5 Cables exposed to physical damage? | | | |
| | 6 Unsecure/unfirm connections or connectors? | | | |
| | 7 Incorrect grounding connections or connectors? | | | |
| 10. Power house foundation: | 1 Broken or cracked foundation? | | | |
| | 2 Poor concrete mixture? | | | |
| | 3 No concrete apron around power house? | | | |
| | 4 Insufficient foundation depth? | | | |
| | 5 Foundation too small for power house? | | | |
| | 6 Gaps between foundation and power house walls? | | | |
| | 7 Erosion or cavitation underneath foundation? | | | |
| 11. Power house general condition: | 1 Plaster, paint falling off walls? | | | |
| | 2 Cracked, damaged walls? | | | |
| | 3 Cracked, damaged floor? | | | |
| | 4 Rust or corrosion on metal walls? | | | |
| | 5 Doors are not closing? | | | |
| | 6 Windows are not closing? | | | |
| | 7 Waste materials left by contractor? | | | |
| | 8 Untidy finishing? | | | |
| | 9 Signs of animals entering? | | | |
| 12. Power house ventilation: | 1 Ventilation openings not on all power house walls? | | | |
| | 2 Power house too hot inside? Note temperature (°C) | | | °C |
| | 3 Ventilation openings dirty or blocked? | | | |
| | 4 Ventilation openings do not stop insects to enter rooms? | | | |
| | 5 Ventilation openings allow animals (e.g. snakes) to enter rooms? | | | |
| 13. Power house flooding prevention: | 1 Foundation height is insufficient to prevent water entry? | | | |
| | 2 No external water diversion channels or aprons? | | | |
| | 3 Roof is leaking? | | | |
| | 4 Ventilation openings or windows are leaking? | | | |
| | 5 Land slide risk at site? | | | |
| | 6 Flooding risk at site? | | | |

| Category | Indicator | TRUE | FALSE | How many?/Comments? |
|--|---|------|-------|---------------------|
| 14. Fence and gate: | 1 Missing or broken fence sections? | | | |
| | 2 Locks or keys for fence gate missing? | | | |
| | 3 Much rust or corrosion on metal fence or gate? | | | |
| | 4 Fence leaning? | | | |
| | 5 Fence foundations poor, not existing or crumbling? | | | |
| | 6 Fence too high thus do not prevent animals to enter? | | | |
| | 7 No fence installed? | | | |
| 15. Distribution grid pole installation: | 1 Poor/inappropriate material used for poles? | | | |
| | 2 No concrete foundations for poles? | | | |
| | 3 Incorrect or broken cable bracket and tensioner? | | | |
| | 4 Poles leaning or not securely anchored? | | | |
| | 5 Poles inappropriately placed (e.g. in road, driveway)? | | | |
| | 6 Poles spacing is incorrect (standard: max 40 m apart)? | | | |
| | 7 Poles placed too close to trees? | | | |
| 16. Distribution grid wiring: | 1 Cables too slack and can be touched without ladder? | | | |
| | 2 Cables not properly secured to pole brackets? | | | |
| | 3 Incorrect cables used? | | | |
| | 4 Exposed copper or aluminium wires? | | | |
| | 5 Poor or exposed cable connections or connectors? | | | |
| | 6 Poor grounding connections or connectors? | | | |
| | 7 Cables touching sharp edges? | | | |
| | 8 Cables crossing over and resting on other distribution cables? | | | |
| | 9 Cables going through trees and resting on branches? | | | |
| | 10 Cables resting on metal surfaces (e.g. building roofs)? | | | |
| | 11 Cables vulnerable to physical damage? | | | |
| 17. Streetlight installation: | 1 Many streetlights not working? | | | |
| | 2 Improper connection cable used? | | | |
| | 3 Cables not protected or secured, but hanging loose? | | | |
| | 4 Cable connection exposed to direct sunlight and rain? | | | |
| | 5 Lamps are not covered or weather protected? | | | |
| | 6 Unsuitable placing of streetlight (e.g. shining into trees)? | | | |
| 18. Household installation: | 1 Lamps, lights not working? | | | |
| | 2 Outlets, sockets not working? | | | |
| | 3 Cables not properly secured to the walls? | | | |
| | 4 Household connection box exposed to weather? | | | |
| | 5 AC distribution cable to household connection box not in conduit? | | | |
| | 6 Energy limiter, meter, MCB damaged, tampered or broken? | | | |
| | 7 Energy limiter, meter not resetting or recording properly? | | | |
| | 8 Exposed copper wires in cable? | | | |
| | 9 Poor or exposed cable connections or connectors? | | | |
| | 10 Untidy cable layout? | | | |
| | 11 No conduits or suitable surface cable (e.g. Surfex) used? | | | |

Appendix 4 KPI questionnaire

| KPI and Sustainability Survey for PVVP System (version 150430) | | | | |
|---|--|--|---|---|
| Location code: | <input style="width: 100%;" type="text"/> | | | |
| <input style="width: 150px;" type="text"/> Date | <input style="width: 200px;" type="text"/> Name of surveyor | <input style="width: 200px;" type="text"/> Signature | | |
| A. General Information | | | | |
| 1. Location code | <input style="width: 150px;" type="text"/> | 2. Village name/hamlet name | <input style="width: 200px;" type="text"/> | |
| 3. Closest city | <input style="width: 150px;" type="text"/> | 4. Distance to closest city | <input style="width: 150px;" type="text"/> km | |
| 5. GSM/GPRS | <input type="checkbox"/> Yes <input type="checkbox"/> No | 6. GPS coordinate powerhouse (in decimal): | <input style="width: 150px;" type="text"/> | |
| 7. Distance to PLN grid: | <input style="width: 100px;" type="text"/> km | | | |
| 8. Site accessibility by | <input type="checkbox"/> Motorcycle | <input type="checkbox"/> Normal car | <input type="checkbox"/> 4x4 car | <input type="checkbox"/> Other |
| 9. Date of commissioning: | <input style="width: 150px;" type="text"/> | 10. Date of operation start: | <input style="width: 150px;" type="text"/> | |
| | Manufacturer | Type | Capacity | Total number |
| 11. PV modules | | | Wp | |
| 12. Battery | | | Ah | |
| 13. Charge regulator | | | | |
| 14. Inverter | | | kVA | |
| 15a. Contractor company that build the PVVP | <input style="width: 100%;" type="text"/> | | | |
| 15b. Organisation that operates the PVVP | <input style="width: 100%;" type="text"/> | | | |
| 15c. Official owner of the PVVP | <input style="width: 100%;" type="text"/> | | | |
| 15d. Funder of the PVVP construction | <input style="width: 100%;" type="text"/> | | | |
| B. Key Performance Indicators in Target Area (Interview with Village Management Team/VMT) | | | | |
| B.1 Households (HH) | | | | |
| 1. Enter the number of households and where they receive electricity from | | | | |
| Households | Connected to PVVP | Connected to PLN grid | Connected to other sources | No electricity |
| <input style="width: 50px;" type="text"/> | <input style="width: 50px;" type="text"/> | <input style="width: 50px;" type="text"/> | <input style="width: 50px;" type="text"/> | <input style="width: 50px;" type="text"/> |
| 2. What is the main reason households have NOT been connected to PVVP? | | | | |
| <input type="checkbox"/> Location: | <input style="width: 250px;" type="text"/> | <input type="checkbox"/> Hand-operated appliances | | |
| <input type="checkbox"/> Financial: | <input style="width: 250px;" type="text"/> | <input type="checkbox"/> PVVP capacity too low | | |
| <input type="checkbox"/> Technical: | <input style="width: 250px;" type="text"/> | <input type="checkbox"/> PVVP operating hours not convenient | | |
| <input type="checkbox"/> Connected to PLN grid | <input style="width: 250px;" type="text"/> | <input type="checkbox"/> Not allowed by PVVP management | | |
| <input type="checkbox"/> Energy supply from generator-set | <input style="width: 250px;" type="text"/> | <input type="checkbox"/> PVVP energy quality not satisfying | | |
| <input type="checkbox"/> Other: | <input style="width: 250px;" type="text"/> | | | |
| Comments: | | | | |
| | | | | |

B.2 Social institutions (SI)

1. Enter the **number** of each type of social institution and where they receive electricity from

| | | Connected to PVVP | Connected to PLN grid | Connected to other sources | No electricity |
|----------------------------|----------------------------|-------------------|-----------------------|----------------------------|----------------|
| Social institutions | Schools | | | | |
| | Health centre | | | | |
| | Community centre | | | | |
| | Religious buildings | | | | |
| | Streetlights | | | | |

2. What is the **main reason** social institutions have NOT been connected to PVVP?

| | |
|---|--|
| <input type="checkbox"/> Location: | <input type="checkbox"/> Hand-operated appliances |
| <input type="checkbox"/> Financial: | <input type="checkbox"/> PVVP capacity too low |
| <input type="checkbox"/> Technical: | <input type="checkbox"/> PVVP operating hours not convenient |
| <input type="checkbox"/> Connected to PLN grid | <input type="checkbox"/> Not allowed by PVVP management |
| <input type="checkbox"/> Energy supply from generator-set | <input type="checkbox"/> PVVP energy quality not satisfying |
| <input type="checkbox"/> Other: | |

Comments:

B.3. Rural businesses (productive use of energy/PUE)

1. Enter the **number** of warungs and other businesses and where they receive electricity from

| | | Connected to PVVP | Connected to PLN grid | Connected to other sources | No electricity |
|---|--|-------------------|-----------------------|----------------------------|----------------|
| Warungs (electricity is used for lighting) | | | | | |

List all businesses (other than warung) and specify the type (using the code below), number of employees and if it is owned/managed by the community or private, male or female, and tick the electricity source. Write each business in a separate row.

| Rural businesses (Productive Use of Energy) | Code | Business (list each one) | | Type (Code) | Number of Employees or Members | Owned/managed by: | | Source of electricity | | | | |
|---|--|--------------------------|--|-------------|--------------------------------|--|------------------------------------|-----------------------|----------|---------------|------|--|
| | | | | | | 1: Community 2: Private 3: Group | M: Mostly male F: Mostly female | PVVP | PLN grid | Other sources | None | |
| | | | | | | | | | | | | |
| | (1) IT – Communication and secretarial services (computer services, internet shop) | | | | | | | | | | | |
| | (2) AP – Agricultural processing (rice huller, hatchery, butchery) | | | | | | | | | | | |
| | (3) FS – Food production and catering (bakery, packaging and bottling, restaurant) | | | | | | | | | | | |
| | (4) CS – Craft and souvenir (tailor, weaver, carpet making, toys production) | | | | | | | | | | | |
| | (5) HH - Health care and hygiene (doctor, nurse, midwife, cleaning services, pest control) | | | | | | | | | | | |
| | (6) MR - Maintenance and repair services (vehicle repair, electronics repair, plumbing) | | | | | | | | | | | |
| | (7) MA - Manufacturing goods (carpentry, metal workshop) | | | | | | | | | | | |
| | (8) Ot - Other | | | | | | | | | | | |

2. What is the **main reason** PUE have NOT been connected to PVVP?

| | |
|---|--|
| <input type="checkbox"/> Location: | <input type="checkbox"/> Hand-operated appliances |
| <input type="checkbox"/> Financial: | <input type="checkbox"/> PVVP capacity too low |
| <input type="checkbox"/> Technical: | <input type="checkbox"/> PVVP operating hours not convenient |
| <input type="checkbox"/> Connected to PLN grid | <input type="checkbox"/> Not allowed by PVVP management |
| <input type="checkbox"/> Energy supply from generator-set | <input type="checkbox"/> PVVP energy quality not satisfying |
| <input type="checkbox"/> Other: | |

Comments:

B.4 Energy supply in general

1. Is a kWh-meter installed in the powerhouse? No Yes If yes, current reading: kWh

2. Is an hour-meter installed in the powerhouse? No Yes If yes, current reading: hours

3. Is a remote monitoring system installed in the powerhouse? No Yes

4. Any problems with the kWh-meter? No Yes,

5. Any problems with the-hour meter? No Yes,

6. Any problems with the remote monitoring system? No Yes,

7. If "Yes" in 6: What are the reasons for the monitoring system giving problems?
 Operator does not understand the messages Operator not familiar with computers
 Operator does not know what to do Only "Error" messages shown
 Computer is broken Other:

8. Supply of electricity to community: 24 hours/day From: 00:00 to: 00:00 Days per week

| | | | | | | |
|---|---|---|---|---|---|---|
| S | M | T | W | T | F | S |
| S | M | T | W | T | F | S |

9. Is the PVVP operating at the moment? Yes, very well No, since
 Yes, but with problems

10. If "No" or "Yes, but with problems" in 9: What are the reasons that PVVP does not deliver energy?
 Insufficient sunshine Inverter broken Operator not available
 Solar panels defect Outside solar cables damaged Management not available
 Battery defect Cables in powerhouse damaged Lightning strike
 Controller defect Grid cables damaged Other:

11. If "No" in 9: When will electricity be available again?
 Next few days Next few weeks Not sure

12. Do you know whom to contact when problems occurred? No Yes

B.5 Quality of energy (ask those who do not belong to VMT)

1. How satisfied are most customers with the quality of electricity provision? Very satisfied Mostly satisfied
 Satisfied Not satisfied

2. Do you have frequent blackouts? No Yes

3. Do you observe frequent light flickering? No Yes

4. Did appliances break due to insufficient quality of electricity? No Yes

5. Do customers complain about insufficient amount of energy per day?
 Yes, most customers complain Yes, a few customers complain
 Yes, but only businesses complain No

6. Are streetlights working?
 Yes, all streetlights working Yes, most streetlights working
 Only few streetlights working No streetlights working

7. What type of replacement lights is easily available for customers?
 LED Incandescent
 CFL None

(Interview with management chairperson and treasurer)

C.1 Village Management Team (VMT)

1. Salaries: Fixed amount Defined as % of revenue No salary

| Function | 2a. Name | 2b. Phone number | 2c. Age | 2d. Gender | | 2e. Salary (IDR/month or % of revenue) | 2f. Period |
|------------|----------|------------------|---------|------------|---|---|------------|
| | | | | M | F | | |
| Operator 1 | | | | | | | |
| Operator 2 | | | | | | | |
| Secretary | | | | | | | |
| Accountant | | | | | | | |
| Manager | | | | | | | |
| | | | | | | | |
| | | | | | | | |
| | | | | | | | |

Total salary: _____

C.2 Condition of the administration books

1. Are there any administration books have been used by VMT? Yes No

| | Not present | Not used | Used | Properly used |
|-----------------------------|-------------|----------|------|---------------|
| 2a. Customer data book | | | | |
| 2b. Log book | | | | |
| 2c. Tariff and/or rule book | | | | |
| 2d. Budget book | | | | |
| 2e. Manual for operator | | | | |
| 2f. Other: | | | | |

3. Other bookkeeping system, please specify:

C.3 Team organisation

1. Are there any regular village meetings on PVVP? Yes No _____ times since start of operation

2. Are there any regular elections or reorganisations? Yes No _____ times since start of operation

3. Main reasons for irregular reorganisation (if any):

- Only regular reorganisation
- Members left the village
- Members are too busy
- Members are paid too little
- Members are not interested
- Members are not sufficiently skilled
- Other: _____
- Other: _____

4. Who provided trainings and/or introductions for the new staff?

- No trainings
- Old staff
- Contractor staff
- Other: _____

5. Do you exchange your experiences with management teams from other PVVPs?

- No
- Yes, with: _____

C.4 Tariff

1. What kind of tariff system is applied?

- Flat rate depending on the number of appliances
- Fixed rate
- Rate per kWh
- Other: _____

2. Is there special "social tariff" for certain people?

- Yes No How: _____

3. Is there special tariff for social institutions?

- Yes No How: _____

4. Special tariff for **productive use of energy**? Yes No How: 0.5A 1A 2A 3A
5. Are **MCBs** in use? No Yes, size: 0.5A 1A 2A 3A
6. Different size MCB in different households? Yes No
7. Several households share MCB? Yes No
8. Are **energy limiters** in use? Yes, limit Wh per day No
9. Different limiter setting for different customers? Yes No
10. If "Yes" in 9, please specify:
11. Did people pay a **connection fee**? Yes How much: IDR No
12. Connection fee includes the household installation? Yes No
13. How many HH pay which tariff per **month** (current status of customers)?

| | Number of HH | Tariff (IDR/month/HH) | Total expected amount (IDR/month) |
|----------|--------------|-----------------------|-----------------------------------|
| Tariff 1 | | | |
| Tariff 2 | | | |
| Tariff 3 | | | |
| Tariff 4 | | | |
| Tariff 5 | | | |

Total: _____

14. How is the tariff collected?
 Staff walking from house to house People come to a specific place to pay Other method (specify)

Specify:

15. What happens if a customer does not pay the electricity fee?

- None Penalty fee of IDR _____
- Disconnection after 1 month Other: _____
- Disconnection after 6 month

16. How often the consequences of non-paying customers have been applied?

- Often Seldom Not yet applied

C.5 Financial administration (observe the book or ask VMT for data from the **last three months**)

1. Any financial records available? No Yes (If yes, complete the table below:)

| | Month 1: | Month 2: | Month 3 (current): |
|--|----------|----------|--------------------|
| 2. Monthly collected fee (according to the book) | | | |
| 3. Monthly maintenance cost (no cost for breakages) | | | |
| 4. Total expense for VMT member salary | | | |
| 5. Incidental expenses (repairment cost, etc.) | | | |
| 6. Monthly savings | | | |

7. Savings are kept in:

- PVVP dedicated bank account Treasurer cash box
- Cooperative saving account Other: _____

8. **Significant expenditures or repair works** happened so far, type and amount:

| Type of repair/replacement | Total amount spent (IDR) | Date of repair |
|----------------------------|--------------------------|----------------|
| | | |
| | | |
| | | |
| | | |

D. Operation and Maintenance

(Interview with operator)

D.1 General customer behaviour

1. Is there any abuse of electricity supply infrastructure by customers?

- | | |
|---|---|
| <input type="checkbox"/> No | <input type="checkbox"/> Yes, improper connections between houses |
| <input type="checkbox"/> Yes, bypassing the circuit breaker (MCB) | <input type="checkbox"/> Yes, vandalism of the PVVP system |
| <input type="checkbox"/> Yes, bypassing the energy limiter | <input type="checkbox"/> Inappropriate use of electrical appliances |
| <input type="checkbox"/> Yes, improper connection from grid to houses | <input type="checkbox"/> Other: _____ |

D.2 Periodic site check and supporting equipment availability

1. Is a tool box available on site?

No Yes

2. Are manual books available on site?

No Yes

3. Known spare parts vendor available?

No Yes

Name _____

Location _____

Phone number _____

4. Solar power technician available?

No Yes

Name _____

Location _____

Phone number _____

5. Log book filled regularly?

No Yes

6. What repairs and maintenance had been conducted since commissioning and how regularly?

| | Not yet | Once every 6 months | Once a month | Weekly | Daily |
|--------------------------------------|---------|---------------------|--------------|--------|-------|
| a. Solar panels replaced | | | | | |
| b. Solar panels cleaned | | | | | |
| c. Shading on solar panels removed | | | | | |
| d. Plant cutting to avoid shading | | | | | |
| e. Charge controller replaced | | | | | |
| f. Inverter replaced | | | | | |
| g. Batteries replaced | | | | | |
| h. Monitoring computer restarted | | | | | |
| i. Monitoring computer replaced | | | | | |
| j. Outside solar cables repaired | | | | | |
| k. Powerhouse power cables repaired | | | | | |
| l. Powerhouse sensor cables repaired | | | | | |
| m. Powerhouse maintenance | | | | | |
| n. Cleaning of power house | | | | | |
| o. Distribution grid cables repaired | | | | | |
| p. Customer energy limiter replaced | | | | | |
| q. Streetlights repaired | | | | | |

List of photos to take

Save photos of each location in one folder!

Create sub folder consisting of:

- Photos of inside powerhouse
- Photos of outside powerhouse
- Photos of distribution network and connection
- Other

Name the photos according to this format: Sitecode_Item.jpg (use the automatic numbering on document explorer)

For example: the third photo of "Battery" at site SulBarS07 will be named: **SulBarS07_Battery (3).jpg**

Take photos as specified by the following list:


| | |
|----------------|--|
| - Other | First page of KPI questionnaire (with the site code written!) |
| - Outside | Around the outside of the powerhouse |
| - Outside | Surroundings of system |
| - Outside | Solar array (landscape) |
| - Outside | Solar array orientation (compass reading overlay) |
| - Outside | Solar module (randomly on some spots, be alert for damage/breakage!) |
| - Outside | Details of cabling at solar array |
| - Inside | Inside powerhouse (with battery, inverter, and monitoring system visible) |
| - Inside | Battery |
| - Inside | Charge controllers |
| - Inside | Inverters |
| - Inside | Details of cabling inside the powerhouse |
| - Inside | Remote monitoring system (RMS) |
| - Inside | Connection and distribution box in the powerhouse or in the panel box |
| - Distribution | Distribution pole and cables |
| - Distribution | Streetlights |
| - Distribution | MCB and energy limiter |
| - Distribution | Public television |
| - Distribution | HH connection |
| - Other | Existed administration books (if any) |
| - Other | Examples of rural businesses including warung (with a person(s) demonstrates their activities) |
| - Other | People in actions (e.g. operator cleaning PV module, inspector checking the installation, operator training) |
| - Other | Access road to the village |
| - Other | Village chief (when agreed upon) |
| - (Dependant) | Detail photo if any installation looks wrong or unsure (put in sub folder depending on the topic) |

Appendix 5 Manual for KPI questionnaire

| A. General Information | | |
|------------------------|--------------------------------|---|
| No. | Question | Explanation |
| 1 | Site code | FILL IN before survey , check in database |
| 2 | Village/hamlet name | FILL IN before survey , check in database |
| 3 | Closest city | What is the closest city to the site |
| 4 | Distance to closest city | Give the distance to the aforementioned closest city in km |
| 5 | GSM/GPRS | <ol style="list-style-type: none"> 1. If GSM signal is available in location, then tick Yes 2. If GSM signal is not available in location, then tick No Check in PVVP location with a GSM cell-phone. If signal is present even though weak (one signal bar/strip), consider that the signal is available, then tick Yes |
| 6 | GPS coordinate powerhouse | <ol style="list-style-type: none"> 1. If GPS coordinate is available in database, then FILL IN before survey 2. If GPS coordinate is not available in database, mark GPS coordinate at the PVVP powerhouse location using the handheld GPS device, then FILL IN. 3. Else, if none of that is possible or practical, leave it EMPTY. |
| 7 | Distance to PLN grid | <ol style="list-style-type: none"> 1. If PLN grid is available in "TARGET AREA", FILL IN with 0 km 2. If PLN grid is not available in "TARGET AREA" but there is in certain distance from it, check by asking to locals or use car/motorcycle speedometer during travel, then FILL IN. 3. Else, if none of that is possible or practical, leave it EMPTY. <i>Explanation of TARGET AREA at Part B (key terminology)</i> |
| 8 | Accessibility by | TICK for all that might apply or available (can be more than one) |
| 9 | Date of commissioning | FILL IN with format day/month/year e.g. 25/07/2012 Date of commissioning is the time when commissioning process (civil structure check, electrical check, etc.) had been completed |
| 10 | Date of operation start | FILL IN with format date/month/year e.g. 30/08/2012 Date of starting operation is the time when first customer had received electricity from the PVVP |
| 11 | PV modules specification | Check from the PV module nameplate. Fill in the brand/manufacturer, type, capacity, and total number. <i>If no information is available from the nameplate, ask to the operator.</i> |
| 12 | Battery specification | Check from the battery nameplate. Fill in the brand/manufacturer, type, capacity, and total number. <i>If no information is available from the nameplate, ask to the operator.</i> |
| 13 | Charge regulator specification | Check from the charge regulator nameplate. Fill in the brand/manufacturer, type, capacity, and total number. <i>If no information is available from the nameplate, ask to the operator.</i> |
| 14 | Inverter specification | Check from the inverter nameplate. Fill in the brand/manufacturer, type, capacity, and total number. <i>If no information is available from the nameplate, ask to the operator.</i> |
| 15 | Name of contractor company | FILL IN with the company name of contractor as in database. |

| B. Key Performance Indicator in Target Area |
|--|
| <p>Key Terminology:</p> <ul style="list-style-type: none"> • HH is Household, a family life in one single building. • SI is Social Institution (i.e. school, community centre, health centre, religious building, streetlights etc.). • PUE is Productive Use of Energy application. It includes any kind of small enterprise that makes use of electricity: <i>i.e. a warung (kiosk), rice/coffee processing machine, workshop, hatchery, tailor, etc.</i> • Customer is any HH/SI/PUE inside the PVVP Target Area (explained below). • Target Area is a set of area consisted of HH, SI, and PUE that were intended to be connected according to the plan. It may |

consist part of a village (left figure), or parts of two villages (right figure). It is the PVVP Target Area that will be the focus of KPI survey. This information is available from Village Chief or VMT.



GENERAL REMARK for PART B

In this part, you will need to fill the boxes with the number of HH, SI and PUE available inside Target Area.

This part of questionnaire absolutely needs to be filled!

Question 1 Further explanations for B.1 (Households), B.2 (Social Institutions), B.3 (Productive Use of Energy)

| | |
|--------------------------------|---|
| Connected to the PVVP | <ul style="list-style-type: none"> Each customer is considered as connected to PVVP if they had connection devices/wires to PVVP and formally accepted as customer by the VMT <i>for at least one month ago (according to the last record of VMT or the last figure they remember if there is no record).</i> If a customer had connection devices but it was disconnected by the VMT permanently due to sanction or lack of PVVP capacity then it is not counted toward the number. Illegal connection does not count. <p><i>Incidental use due to wedding celebration, funeral or other INCIDENTAL social event does not count.</i></p> |
| Connected to the PLN grid | <p>Each customer considered as connected to PLN if they had legal or illegal (it does not matter) connection to PLN and not permanently disconnected by any reason. Find this data by asking the VMT. Estimation is acceptable.</p> <p><i>Incidental use due to wedding celebration, funeral or other INCIDENTAL social event does not count.</i></p> |
| Connected to the other sources | <p>Each customer is considered as connected to other sources if they had any active and regularly used electricity sources or generation devices e.g. genset. A backup generator-set does not count. Find this data by asking the VMT. Estimation is acceptable.</p> <p><i>Incidental use due to wedding celebration, baby birth celebration, funeral or other INCIDENTAL social event does not count.</i></p> |
| Not connected | <p>Considered not connected at all if they had no electricity source can be used in daily basis. Find this data by asking the VMT. Estimation is acceptable.</p> |

| No. | Question | Explanation |
|-----|--|---|
| 2 | What is the main reason HH/SI/PUE have NOT been connected to PVVP? | <p>TICK all that apply. Try to focus on main reason(s).</p> <p><i>Location:</i> e.g. houses are too far away</p> <p><i>Financial:</i> e.g. no money for connection fee, no fund available for monthly fee, no money for appliances, etc.</p> <p><i>Technical:</i> if the reasons is manly technical e.g. no technical equipment available, not enough capacity installed</p> |
| 3 | What are future prospects for the connection rate of HH/SI/PUE? | <p>TICK all that apply but try to focus on the most realistic prospect. This question intends to identify the potential of future PVVP customers.</p> |

B.2 Social Institution

| | | |
|---|---------------------|---|
| A | Schools | <i>PAUD, SD, SMP, SMA.</i> |
| B | Health centre | <i>Puskesmas, Posyandu, Hospital.</i> Doctor or midwife's house is not considered as health centre. |
| C | Community centre | Youth centre, community meeting building, village hall, etc. |
| D | Religious buildings | Mosque, <i>musholla</i> , church, etc. |

| E | Streetlights | The streetlights installed as part of the project. |
|-------------------------------------|--|---|
| B.3 PUE | | |
| PUE | The <i>Business</i> table includes any PUE beside warungs. List one of each business existing. | |
| B.4 Energy Supply in General | | |
| No | Question | Explanation |
| 1 | Is a kWh meter installed? | If a kWh meter is installed and works properly, TICK the “Yes” box <i>Remember to take a picture of the total kWh recorded!</i> If a kWh meter is not installed, TICK the “No” box. |
| | (kWh meter) Current reading | <ul style="list-style-type: none"> ▪ If and only if a kWh-meter is installed and working properly without recorded problems, FILL IN according to the meter. ▪ It is the kWh meter inside powerhouse, and NOT in the household. ▪ Be careful on meter reading; notice the decimal point display (no decimal point, one decimal point, two decimal points). Normally the decimal point of an analog kWh meter display will be coloured differently. ▪ Make sure you understand the kWh meter display before writing any number. |
| 2 | Is an hour meter installed? | If an hour meter is installed and worked properly TICK the “Yes” box <i>Remember to take a picture of the total hours recorded!</i> If an hour meter is not installed, TICK the “No” box. |
| | (hour meter) Current reading | Fill in the hour reading according to the meter. |
| 3 | Is solar monitoring system installed? | TICK “Yes” or “No” as applicable. This is the Remote Monitoring System (RMS) as specified in the specification document. |
| 4 | Have you ever had problems with the kWh meter? | If yes, specify the problems. Problems are the ones caused interruption in the measurement. This question is to identify if the kWh recorded can be compared to kWh records from other sites. Interruption of recording, i.e. PVVP running without metering it, can cause a bias within the analysis. TICK the “Yes” box if kWh-metering has been interrupted since installation of the meter. Otherwise, tick “No”. |
| 5 | Have you ever had problems with the hour meter? | If yes, specify the problems. This question is to identify if the hours recorded can be compared to operational hour records from other sites. Interruption of recording, i.e. PVVP running without metering it, can cause a bias within the analysis. TICK the “Yes” box if hour meter has been interrupted since installation of the meter. Otherwise, tick “No”. |
| 6 | Have you ever had problems with the monitoring system? | If yes, specify the problems e.g. error message, not connected, etc. |
| 7 | What are the reasons of monitoring system giving problems? | If yes on number 6, TICK all reasons that apply. |
| 8 | Supply of electricity to community | <ul style="list-style-type: none"> ▪ TICK 24 hours/day and CROSS the days when PVVP works for 24 hours/day ▪ If there are days when PVVP does not work 24 hours/day, specify the time and CROSS the days when PVVP works on the specified time. |
| 9 | Is the PVVP operating at the moment? | <ul style="list-style-type: none"> ▪ If PVVP still provides electricity regularly until the day of KPI Survey, TICK “Yes, very well”. ▪ If PVVP is inactive for more than one month, TICK “No, since” and specify the date it stopped operating. ▪ If there are some problems that recently cause interrupt the regular operations, TICK “Yes, but with problems” <p><i>If PVVP is inactive during the survey due to maintenance, special day (Friday, Sunday), and <u>not</u> because of technical breakdown or non-functioning VMT, and there is clear evidence of regular PVVP use, TICK “Yes, very well”</i></p> |
| 10 | If “No” or “Yes, but with problems” in 9: What are the reasons? | If question 9 is answered as “no” or “yes, but with problems”, TICK all reason(s) applied and write the reason on blank line if not in the list. |
| 11 | If “No” in 9: When will | If question 9 is answered as no, TICK one that applies. |

| | | |
|----|---|--|
| | electricity be available again? | |
| 12 | Do you know whom to contact when problems occurred? | TICK one that applies. If “yes” specify the name/contact/workshop/etc. |

B.5 Quality of Energy

| No | Question | Explanation |
|----|---|---|
| 1 | How satisfied are most customers with the quality of electricity provision? | TICK one that applies. |
| 2 | Do you have frequent blackouts? | TICK “yes” if blackouts occur frequently e.g. more than once a week. TICK “no” if blackout does not occur, or only happens a few times within a month and do not affect the overall supply of electricity. |
| 3 | Do you observe frequent light flickering | TICK “yes” if light flickering occurs frequently e.g. each day, or each week. TICK “no” if light flickering does not occur, or only happens a few times that don’t affect the overall supply of electricity. |
| 4 | Did appliances break due to insufficient quality of energy? | TICK “yes” if there had been appliances broken due to unstable energy supply. |
| 5 | Do customers complain about insufficient amount of energy per day? | TICK one that applies. |
| 6 | Are streetlights working? | TICK one that applies. |
| 7 | What type of replacement lamps is easily available for customers? | TICK all that apply. |

C. Administration and Management (Interview with management chairperson and treasurer)

C.1 Village Management Team (VMT)

| No | Question | Explanation |
|----|----------|---|
| 1 | Salaries | TICK one answer and specify if the management team is paid and how. |

2. Try to fill all the function of VMT being asked. Phone number and name of at least one person should be recorded for future means of communication.

If there is a person who have more than one function, write his/her name in every function s/he fulfils. This is an example of how it should be filled in this situation:

| Function | 2a. Name | 2b. Phone number | 2c. Age | 2d. Gender | | 2e. Salary (IDR/month or % of revenue) | 2f. Period (month) |
|----------------------|--------------|------------------|---------|------------|---|---|--------------------|
| | | | | m | f | | |
| Operator 1 | Budi Rohman | 0816XYZ123 | 40 | x | | Rp 400 000 | 2 |
| Operator 2 | Rahmat Wisnu | 0815ABC246 | 50 | x | | Rp 600 000 | 8 |
| Secretary | Vika Riana | 0852BEF664 | 25 | | x | Rp 400 000 | 8 |
| Accountant | Vika Riana | Look above | 25 | | x | Look above | Look above |
| Manager | Rahmat Wisnu | Look above | 50 | x | | Look above | Look above |
| Total salary: | | | | | | 1,400,000 | |

By identifying two names which are identical (Rahmat Wisnu and Vika Riana), we can know that there are three persons in total in the VMT. In order to avoid time consuming repetition of phone number or salary writing, make a symbolic sign, for example Look above or == as long as it is consistent and understandable.

Try to identify since when they are accepted to the VMT in order to find out about the reorganisation, for example Budi Rohman recently joined the team as operator and has been working for 2 month. Sum up the total amount of salary that is spent for the management team, to cross check this data with the financial status in section C.5.

C.2 Condition of Administration Books

Firstly, ask if any administration books have been used by the VMT. Not all sites have books as indicated. If VMT has other books, but the function is more or less similar, you can say they have the books. If they have different book with different function from the list, specify what book it is.

Key terminology about the books:

1. **Customer Data Book:** book in which all customers are listed and accountant records fee collection.
2. **Log Book:** book in which operator record technical performance, trouble and maintenance schedule.
3. **Tariff and Rule Book:** book that explains the tariff system, rules/sanctions about illegal connection, late payment, connection application etc. This could only be a notebook and does not have a special format or design.
4. **Cash Book:** book that lists the income, maintenance and salary expense, spare part replacement expense etc.
5. **Manual for Operator:** book provided by the PVVP contractors regarding the solar power components.

Key terminology about the criteria:

- **Not Present:** the book is **not physically available** on the site during survey for some reason or excuse. As long as the VMT cannot show it, then **TICK as not present**.
- **Not Used:** the book is physically available in the location during KPI Survey and **can be photographed** but never used (completely blank or just filled for first month), **TICK as not used**.
- **Used:** the book is physically available in the location during KPI Survey and **can be photographed**, there is missing information, but **IMPORTANT DATA** (monthly expense, frequency of breakdown etc.) can be estimated roughly from the book, **TICK as USED**.
- **Properly Used:** the book is physically available in the location during KPI Survey and **can be photographed; IMPORTANT DATA** (monthly expense, frequency of breakdown etc.) can be estimated with good confidence from first month of operation until the day of survey.

| C.3 Team Organisation | | |
|-----------------------|---|--|
| No | Question | Explanation |
| 1 | Are there any regular meetings? | If there is scheduled meeting monthly, TICK "Yes" , FILL box times since start of operation. If there is no scheduled meeting, TICK "No" . |
| 2 | Are there any regular elections/reorganisations? | If reorganisation had been scheduled for certain years in the rule, TICK "Yes" , FILL box times since start of operation. If there is no scheduled reorganizations, TICK "No" . |
| 3 | Main reasons for reorganisation (if any) | TICK all that apply. (if one people already change, it count as reorganisation) |
| 4 | Who provided trainings and introductions for the new staff? | TICK all that apply. Any training whether formal or informal is accepted as training as long as they consist of (ask the VMT): 1. What to do in normal situation 2. What to do in problematic situation |
| 5 | Do you exchange your experiences with VMTs from other PVVPs? | If you exchange your experience about PVVP in official or informal way with other PVVP management teams TICK "Yes" and specify the name of the PVVP. |
| 6 | Any complaints/comments from costumers concerning management of PVVP? | TICK one that applies. Specify if there is any comment. |
| C.4 Tariff | | |
| No | Question | Explanation |
| 1 | What tariff system applied? | TICK for one that most appropriate, choose the latest effective system used. Ask the VMT. |
| 2 | Special " social tariff " for poorer people? | If there is a special tariff for people who earn less than average, TICK "Yes" and specify the tariff. |
| 3 | Special tariff for social institutions ? | If there is a special tariff for social institutions, TICK "Yes" and specify the tariff. |
| 4 | Special tariff for productive use of energy ? | If there is a special tariff for productive use of energy (i.e. businesses), TICK "Yes" and specify the tariff. |

| | | |
|----|--|---|
| 5 | Regular tariff increase (e.g. 5% per year)? | If there is a regular tariff increase, TICK "Yes" and specify the system/the increase. |
| 6 | Are MCBs in use? | If MCBs are installed in the HH, TICK "Yes" and choose all sizes installed. |
| 7 | Different MCB size in different HH? | If different sizes of MCBs are installed among the connected households, TICK "yes". |
| 8 | Several HH share an MCB? | If there are households share one MCB, TICK "Yes". For example this could apply on households that live in the same building. |
| 9 | Are the energy limiters in use? | TICK one that applies. If "Yes", specify the setting: Wh/HH/day. |
| 10 | Different energy limiter settings for different customers? | TICK one that applies. If "Yes", specify the difference in No. 11. |
| 12 | Did people pay a connection fee? | If the customers paid a connection fee to use electricity from the PVVP, TICK "Yes" and specify the average amount of this connection fee. |
| 13 | Did connection fee include the household installation? | Household installation means the physical connection to the PVVP, i.e. wiring, switches, MCB, etc. |
| 14 | How many HH pay which tariff per month (current status of customers)? | According to the current status (which should be equivalent with the customer data book entries), give the number of households, tariff per month and total amount of payment from each tariff group. Sum up the expected amount of monthly tariff to cross check this data with the financial status in section C.5. |
| 15 | How is the tariff collected? | TICK one that applies or describe method of collecting the tariff. |
| 16 | What happens to the customer who does not pay the electricity fee? | TICK all that apply or specify sanctions on blank line if not in the list. Ask the VMT. |
| 17 | How many times the consequences have been applied? | TICK for one that most appropriate. Estimation is acceptable. Ask the VMT. |

C.5 Financial Administration

Firstly ask if any financial records available. If "Yes", complete the table below.

Before entering the financial data, write the last three completed month. For example: If the date of survey is 15 May, the last three completed month are February, March and April and should be entered in the following order:

| | | |
|--------------------------|-----------------------|--------------------------------|
| Month 1: <u>February</u> | Month 2: <u>March</u> | Month 3 (latest): <u>April</u> |
|--------------------------|-----------------------|--------------------------------|

| No | Question | Explanation |
|----|---|--|
| 1 | Monthly expected fee | Calculate according to the rule or tariff book. Check how many customers exist in each of the 3 months and how much are they supposed to pay according to tariff book. |
| 2 | Incidental income (everything beyond monthly fee) | The total amount of income beyond monthly household fee for each of the 3 months. |
| 3 | Monthly collected fee (according to the book) | Real total fee collected for each of the three months. This only includes the income by monthly tariff and not the incidental income stated above. |
| 4 | Monthly maintenance cost (no cost for breakages) | Maintenance costs for each of the 3 months. This includes regular maintenance expenses or small reparations at civil construction but NOT the costs to fix major breakages! |
| 5 | Total monthly expenses for VMT salary | Get the data from section C.1! |
| 6 | Incidental expense at that month | Incidental expenses for each of three months. Those include any expense that is not included in the normal O&M costs (e.g. breakages, etc.) |
| 7 | Monthly savings | Monthly savings should equal to monthly income (tarif and incidental income) minus monthly expenses (maintenance, salary, and incidental expenses). |
| 8 | Total current savings | Ask the VMT or observe from cash book. This is the total amount of currently available money for PVVP. |
| 9 | Savings are placed in | TICK one that applies. If not in the list, specify the placement of savings on blank line. |

| | | |
|--|---|---|
| 10 | Which significant expenditures/repair works happened so far, type and amount | Specify if there had been expenditures for reparation of major breakages or non-regular maintenances. For example breakages of powerhouse/PV modules/inverter/etc. |
| D. PVVP Operation and Maintenance (interview with operator) | | |
| D.1 General Customer Attitude | | |
| No | Question | Explanation |
| 1 | Is there any abuse of electricity supply infrastructure by customers? | TICK all that apply. |
| D.2 Periodic Site Check and Supporting Equipment Availability | | |
| No | Question | Explanation |
| 1 | Is a tool box available on site? | Tool box does not necessarily a box, but any kind of container that neatly holds essential equipment like: screwdriver, plier, wrench etc. On site means either in the powerhouse or in the operator's house. |
| 2 | Manual books available on site? | [self-explanatory] |
| 3 | Known spare part vendor available? | Any kind of shop that can provide bolts, nuts, cables, MCBs, fuses etc. Note down the name, location, and phone number of the shop (if possible). |
| 4 | Known repair workshop available? | Specialised PVVP components repair workshop. Note down the name, location, and mobile phone number of the workshop/technician. |
| 5 | Log book filled regularly? | It is considered regular if at least all month are filled. |
| 6 | What repairs and maintenances had been conducted since commissioning and how regularly? | [self-explanatory] Quantify how often the system has experienced such occurrences within the last year. Fill in a number (estimation is possible). If no such occurrence was observed, please enter a "0". |

Mini-Grid Service Package for PVVP 2015 Technical Summary Sheet

| | | | |
|-------------------|-----------------------|-------------------------|--------------------------------|
| Site code: | As per checklists/KPI | Survey date: | As per KPI |
| Village name: | As per KPI | Commissioning date: | As per KPI |
| District: | As per site list | Paket number: | As per site list |
| Province: | As per site list | Contractor name: | As per KPI |
| System size (kW): | As per checklists/KPI | Total score (%): | Average of scorings 1, 2 and 3 |

| | | | | | |
|----------------------------------|-------------|--------------------------|------------|--------------------------|--|
| PV-VP system operational: | Yes: | <input type="checkbox"/> | No: | <input type="checkbox"/> | Comment: As per checklists/KPI |
|----------------------------------|-------------|--------------------------|------------|--------------------------|--|

1. Component compliance

Verification between contract requirements and actual site installation

| Solar PV Modules | | | | | |
|---|--------------------------|-----------|--------------------------|---------------|--|
| Installed capacity: | <input type="checkbox"/> | Fulfilled | <input type="checkbox"/> | Not fulfilled | Fulfilled if all are installed; state capacity (kWp) Additional comments in case of defects (e.g. spots and others) |
| PV module type / brand: | <input type="checkbox"/> | Fulfilled | <input type="checkbox"/> | Not fulfilled | State make and model as per KPI Fulfilled if as per specification |
| PV Array / Support | | | | | |
| Frame material: | <input type="checkbox"/> | Fulfilled | <input type="checkbox"/> | Not fulfilled | Fulfilled if planned material used/ installed; Additional comments in case of defects (e.g. rust etc.) |
| Mounting angle: | <input type="checkbox"/> | Fulfilled | <input type="checkbox"/> | Not fulfilled | Fulfilled if as per specification |
| Orientation / Azimuth: | <input type="checkbox"/> | Fulfilled | <input type="checkbox"/> | Not fulfilled | Fulfilled if facing North (Utara) |
| Grid Inverter (not applicable if Battery Inverter is used) | | | | | |
| Installed capacity: | <input type="checkbox"/> | Fulfilled | <input type="checkbox"/> | Not fulfilled | Fulfilled if installed even if defect; state capacity (kW0) In case of defects additional comment |
| Inverter type / brand: | <input type="checkbox"/> | Fulfilled | <input type="checkbox"/> | Not fulfilled | State make and model as per KPI Fulfilled if as per specification |
| Battery Inverter (not applicable if Grid Inverter is used) | | | | | |
| Installed capacity: | <input type="checkbox"/> | Fulfilled | <input type="checkbox"/> | Not fulfilled | Fulfilled if installed even if defect; state capacity (kW) In case of defects additional comment |
| Inverter type / brand: | <input type="checkbox"/> | Fulfilled | <input type="checkbox"/> | Not fulfilled | State make and model as per KPI Fulfilled if as per specification |
| Solar Charge Controller (not applicable if Grid Inverter is used) | | | | | |
| Installed capacity: | <input type="checkbox"/> | Fulfilled | <input type="checkbox"/> | Not fulfilled | Fulfilled if installed even if defect; state capacity (kW) In case of defects additional comment |
| Controller type / brand: | <input type="checkbox"/> | Fulfilled | <input type="checkbox"/> | Not fulfilled | State make and model as per KPI Fulfilled if as per specification |
| Battery System | | | | | |
| Installed capacity: | <input type="checkbox"/> | Fulfilled | <input type="checkbox"/> | Not fulfilled | Fulfilled: if battery voltage and capacity meets contract; state capacity (kWh) |

| | | | |
|---|-----------|---------------|---|
| Bank Voltage rating: | Fulfilled | Not fulfilled | Fulfilled: if battery bank voltage and capacity meets contract |
| Battery type / brand: | Fulfilled | Not fulfilled | State make and model as per KPI Fulfilled: if as per specification |
| Remote Monitoring System | | | |
| Data connection model: | Fulfilled | Not fulfilled | State make and model as per KPI Fulfilled: if as per specification |
| Data storage active: | Fulfilled | Not fulfilled | State type as per KPI Fulfilled: if data being stored on device or available on computer |
| Pyranometer installed: | Fulfilled | Not fulfilled | State make and model as per KPI Fulfilled: if as per specification |
| Pyranometer active: | Fulfilled | Not fulfilled | State type as per KPI Fulfilled: if data being stored on device or available on computer |
| Balance of System | | | |
| Power house: | Fulfilled | Not fulfilled | As per Technical Sheet Not fulfilled: In case of obvious deviations (incorrect building types or fittings) |
| Electric wiring as specified: | Fulfilled | Not fulfilled | As per Technical Sheet Not fulfilled: In case of obvious deviations (incorrect cables types) |
| Grounding as specified: | Fulfilled | Not fulfilled | As per Technical Sheet Fulfilled: in case that grounding had been done in the solar array yard and for all electrical cabinets and household connections Not fulfilled: in case that even grounding of one cabinet or of other equipment had not been done (serious risk of life and damage to equipment) |
| Combiner boxes as specified: | Fulfilled | Not fulfilled | As per Technical Sheet Fulfilled: if installed as specified In case of defects additional comment |
| Lightning protection as specified: | Fulfilled | Not fulfilled | As per Technical Sheet Fulfilled: if installed as specified Not fulfilled: missing sky counter |
| Distribution panel as specified: | Fulfilled | Not fulfilled | As per Technical Sheet Fulfilled: if installed as specified Not fulfilled: In case of major defects |
| kWh meter as specified and functioning: | Fulfilled | Not fulfilled | As per KPI and Technical Sheet Fulfilled: if installed Not fulfilled: In case of major defects |
| Appliances | | | |
| Energy limiters installed and functioning: | Fulfilled | Not fulfilled | State quantity as per KPI State Wh setting as per KPI Not fulfilled: if more than 10% defective |
| Customer (household and social institution) connections quantity: | Fulfilled | Not fulfilled | State Planned as per site list State Surveyed (HH & SI) as per KPI Not fulfilled: if surveyed is below planned |

| | | | |
|---------------------------------------|-----------|---------------|--|
| Streetlight installed and operating: | Fulfilled | Not fulfilled | State Planned as per contract State Surveyed as per KPI Fulfilled: if installed, even if improper streetlights are used (make additional comment) Not fulfilled: if surveyed is below planned, if more than 10% defective |
| LCD TV installed at community centre: | Fulfilled | Not fulfilled | Not fulfilled: if not installed, if installed in power house |

2. Performance verification

Spot measurements for key components for consistency

| | | | |
|---------------------------------------|-----------|---------------|---|
| PV module output consistency: | Fulfilled | Not fulfilled | In case of defects additional comment Not fulfilled: if inconsistency between different measurement points more than 50% |
| Battery storage acceptable: | Fulfilled | Not fulfilled | State voltage (V) and recorded time (hh:mm) as per Measurement Sheet Fulfilled: if >50VDC, if 48-50VDC (but with additional comments since voltage should be higher) Not fulfilled: if measurement <48VDC |
| Inverter output consistency: | Fulfilled | Not fulfilled | State voltage (V) as per Measurement Sheet In case of defects additional comment (e. g. check voltage at inverter LCD based on photos) Not fulfilled: if measurement of AC voltage is < 10% |
| Distribution grid voltage acceptable: | Fulfilled | Not fulfilled | State voltage (V) as per Measurement Sheet and voltage drop (%) Not fulfilled: >5% related to 220 or 230 V (measurement value: lowest value measured) |

3. Workmanship quality

Review of workmanship as per general quality, health and safety requirements. **Rated 1 (very poor quality/safety risk) – 5 (very good quality)**

General scoring guide:

- 5 = very good, meets required specification
- 4 = good, meets required specification with few faults
- 3 = fair, meets required specifications with several faults
- 2 = poor, below standard, some major faults
- 1 = safety risk, serious faults and shortcomings

| | | | |
|---|------------------------------|---------|--|
| 1 | PV module quality: | Rating: | 1: if > 25% of modules with spots or other defects 2: if 10% to 25% of modules with spots or other defects 3-4: shading on modules, modules with minor defects |
| 2 | PV module array foundation: | Rating: | 1-3: for eroded, partly not exiting foundations, cracked foundations, poor foundation size, insufficient depth |
| 3 | PV array mounting structure: | Rating: | 1: wood or other non-standard material is used |

| | | | |
|----|--|---------|---|
| | | | 2-3: many loose modules, stays, base plates or mounting brackets; if stability concerns; twisted array 4: risk of galvanic corrosion |
| 4 | PV array combiner box wiring: | Rating: | 1-3: If not properly fixed to the support structure and without sealed cable entries; if no glands are used or cable entries not sealed (animals inside) 1-2: if not weather resistant and mounted exposed to UV and rain |
| 5 | External wiring (PV module to power house): | Rating: | 1-3: cables not protected in conduits, supported by channels or vulnerable to damage; in case of improper interconnection of module cable with string cable (e.g. with exposed terminal blocks) 1-2: if incorrect cable types, reduced cross sections or UV exposed cables |
| 6 | Grounding and earthing: | Rating: | 1-2: if grounding of one or more equipment missing or poorly installed 3-4: if wrong cable colour is used, diameter too small |
| 7 | Battery rack: | Rating: | 1: if nothing is provided 2-3: if vulnerable to corrosion (non-galvanised, non-primed metal frame) 3: if wooden or plastic pallets used; if no side bar |
| 8 | Battery terminal connections: | Rating: | 1: if main terminals fully exposed 1-3: if some terminals not covered or just partly covered with plastic foil 4: if main cables not in conduit |
| 9 | Internal power house wiring: | Rating: | 1-2: if exposed cables without insulation, faulty connections posing heat/fire hazard 1-3: if cables not protected in conduits, supported by channels or vulnerable to damage |
| 10 | Power house foundation: | Rating: | 1-3: if extensive chipping, crumbling and cracking of foundation 4: if without apron |
| 11 | Power house general condition: | Rating: | 1: if serious defects, such as broken walls, missing roof sections, unstable structure 2-3: if poor and sloppy finishing, doors and windows don't close, broken ceiling, broken floor, contractor waste materials left on site |
| 12 | Power house ventilation: | Rating: | 1: if battery temperature > 40°C 2: if battery temperature > 35°C 3: if battery temperature > 30°C 3: if one or more walls without passive ventilation openings |
| 13 | Power house flooding prevention: | Rating: | 1-3: if evidence of flooding, if high risk of flooding or land slide, with no precautions taken, foundation < 10cm above ground |
| 14 | Fence and gate: | Rating: | 1-2: if sections missing, or large gaps 3: if strong rusting of bolts and fence; if fence leaning, fence too high from ground |
| 15 | Distribution grid pole installation: | Rating: | 1-2: if not utility standard (or best practice) material and mounting brackets 2-3: if wrongly placed (blocking access routes, cause of potential accidents), if unstable poles, missing foundations and guy wires |
| 16 | Distribution grid wiring: | Rating: | 1-2: if poor cable interconnection (cables just twisted together), insufficient cable height (can be touched without ladder), cable resting on other objects (e.g. house roofs) 1-3: if cables at power house and households not protected |

| | | | |
|----|--------------------------------|---------|---|
| 17 | Streetlight installation: | Rating: | 1-3: in case of very poor cable interconnection (cables just twisted together) 3: if more than 50% not working 3: if non-weather-proof streetlights (e.g. under-roof flood lights) are used |
| 18 | Household installation: | Rating: | 1-3: if cables not protected in conduits, supported by channels or vulnerable to damage; if energy limiters and MCB exposed to weather; if cable not properly interconnected (cables just twisted with poor insulation) |

Items in RED, with very poor workmanship (scoring of 2 or less) pose significant health and safety risk!

| | |
|--|----------|
| Overall rating of Workmanship Quality: (Max. score = 90 → 100%) | % |
|--|----------|

4. Recommendations

Recommendations regarding any possible follow-up with Contractor

| |
|--|
| Listed as per workmanship items above (state: Item #:recommendation.....) Recommendations relevant to contractor after-sales service or correctional work |
|--|

5. Pictures


Pictures of poor quality workmanship as per "Workmanship quality" checklist

| | |
|--|--|
| Caption to state "Item #" from workmanship list above Dimensions: 6x8 cm (if portrait), 8x6 cm (if landscape) | |
|--|--|

Funded by:



Political partner:



Coordinated and implemented by:

