

PV Development and Grid Access Study for a Club Resort in Indonesia

Dr. Matthias Eichelbrönner Managing Director E.Quadrat GmbH & Co. Energy Experts KG

PV Project Development by

Horst Kruse, Jakarta On behalf of GIZ Indonesia, Promotion of Least Cost Renewables in Indonesia (LCORE)

Study works supported by

GIZ Indonesia, Promotion of Least Cost Renewables in Indonesia (LCORE), www.lcore-indonesia.or.id

- 1. Maumere Club Resort and PV Project
- 2. Electrical Infrastructure on the Maumere Island
- 3. Grid Measurements and Data Evalutation



- North coast of Flores Island about 10 km from nearby town of Maumere.
- Sea World Club (SWC) is a sea side resort with gross land area approximately 2.16 hectars and consist of 25 bungalows.
- GIZ LCORE intends to initiate a pilot PV project, considering:
 - Energy consumption to be covered by PV on a net metering basis (yearly balance).
 - Grid downtime should be bridged by a battery storage system.

Maumere









- Electricity supply: 20 kV/380 V transformer 100 kVA
- Supplier: PT PLN through their 8 MW diesel powered grid network (02/2013)
- Customers: private customers and the sea resort
- The installed capacity of the resort: 41.5 kVA, at 380/220 VAC
- The PLN connection point of the sea resort is in the generator house
- The distance between transformer and the generator house is about 300m









- 1. Maumere Club Resort and PV Project
- 2. Electrical Infrastructure on the Maumere Island
- 3. Grid Measurements and Data Evalutation

PLN Maumere Grid

- Around 13.78 MVA installed capacity
- Capable / planned capacity is around 9.7 MVA
- 25 diesel generators
 - 7 PLN owned
 - 18 rented
- Peak load in the evening 8.785 MVA max
- Load during noon 5.62 MVA max
- The predicted / estimated peak load in 2013 is 9.68 MVA (average)

Data February 2013









Source: GIZ LCORE

Overview 20 kV Distribution Network and Measuring Points



- 1. Maumere Club Resort and PV Project
- 2. Electrical Infrastructure on the Maumere Island
- 3. Grid Measurements and Data Evalutation

Load-Management and Grid-Evaluation

- Detailed grid measurement and evaluation
 - Grid monitoring for technical reliable interconnection
 - Evaluation influence PV-System before and after installation
 - Further grid studies for next-step decentralized PV-Systems
 - Diesel Generator operation strategy
 - Diesel-Fuel Consumption



Example Grid Measurement before PV Installation



Findings:

- Voltage fluctuations 205 to 236 V
- Asymmetric phase voltage
- Asymmetric demand to be assumed

Question:

 Maximum PV power feasible? Example Grid Measurement – Demand Side



First Findings:

- Demand side power range
- voltage spread

Questions:

- Demand profile
- PV input profile
- Maximal PV power
- Extra PV grid cable to transformer
- Extra transformer
- Maximum PV power to be determined

Source: Calculations and estimations by E.Quadrat

Evaluation of Parameters to define max PV installation



Source: Calculations and estimations by E.Quadrat



- Recommended PV installation at SWC: 60 kW peak
 PV max connection point = 50 kW (net) + 20% (losses due to PR)
- Grid data evaluation developed methodology to estimate maximum PV power
- Methodology evaluates specific grid data as
 - Voltage to load *Downstream* gradient
 - Voltage spread of *Upstream* system behavior

from grid connection point.



RENEWABLE ENERGY FOR ENERGY SYSTEMS

Thank You for Your Attention!



E.Quadrat GmbH & Co. Energy Experts KG Weinheimerstraße 64a 68309 Mannheim

Handelsregister Mannheim HRA 702149

Telefon +49/(0)621/762 209 6-0 www.equadrat-gmbh.eu